REPORT OF DRINKING WATER SAMPLING FOR LEAD CONTENT AT:

BOONE TRAIL 555 EAST HIGHWAY N WENTZVILLE, MISSOURI 63385



PREPARED FOR:

MRS. ANGELA HAWKINS
DIRECTOR OF MAINTENANCE
WENTZVILLE R-IV SCHOOL DISTRICT
101 SUPPORT SERVICE DRIVE
WENTZVILLE, MISSOURI 63385

PREPARED BY:

J.S. HELD, LLC #6 MEADOW HEIGHTS PROFESSIONAL PARK COLLINSVILLE, ILLINOIS 62234 (618) 343-3590

OCTOBER 2023

DOCUMENT TO BE RETAINED INDEFINITELY

TABLE OF CONTENTS

23-0-448
Drinking Water Sampling for Lead
Wentzville R-IV School District
Boone Trail
555 East Highway N
Wentzville, Missouri 63385

EXECUTIVE SUMMARY

APPENDIX A	Sample Locations/Results
APPENDIX B	Laboratory Analysis
A DDENIDIY C	Cradentials

EXECUTIVE SUMMARY



6 Meadow Heights Professional Park Drive Collinsville, IL 62234 | US

jsheld.com

November 7th, 2023

Mrs. Angela Hawkins Director of Maintenance Wentzville R-IV School District 101 Support Service Drive Wentzville, Missouri 63385

Subject: Results of Drinking Water Testing for Lead Content

Site(s): Boone Trail Elementary

555 East Highway N

Wentzville, Missouri 63385

Dear Mrs. Hawkins

On the morning of October 25th, 2023, J.S. Held performed lead testing of multiple water sources at the Boone Trail Elementary located at 555 East Highway N in Wentzville, Missouri. The sampling was performed by trained and licensed personnel in accordance with USEPA, HUD and State of Missouri Regulations and Guidelines. Work was performed in accordance with the newly amended Missouri Senate Bill 681.

All inspectors involved with sampling activities had EPA approved training in lead. Certifications for our firm and the inspector collecting the samples are included as Appendix C to this document.

All samples were collected on a "first draw" and "second draw" basis. "First draw" is achieved by allowing the water system to rest for at least eight hours prior to sampling in order to collect any existing debris or settlement within the sample. The intent of this sampling is to replicate "worst case scenario" conditions. J.S. Held proposes to collect a second sample from each source as a "follow-up sample" per the Missouri Senate Bill 681 requirements. As such, J.S. Held inspectors met at the school at 5:00 a.m. to collect water samples before the systems were used by staff or students. The State of Missouri and other regulatory agencies recommend that water sources run for at least thirty seconds and as long as two minutes prior to use to avoid settling within the water system.

1

Drinking water samples were collected from Forty-Three (43) different locations throughout Boone Trail Elementary during the sampling event. The water samples were collected from drinking fountains and sinks potentially utilized for cooking or drinking activities at the campus. After sample collection, samples were immediately iced down and delivered to Teklab, Inc. located in Collinsville, Illinois following strict chain of custody procedures. Teklab is a NELAP accredited and State of Illinois licensed laboratory specializing in drinking water analysis. Detailed sampling locations and sample results are located in Appendix A of this report.

The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 micrograms per liter (µg/L). The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 microgram of lead per liter (µg/L). This reporting value equates to 1.0 parts per billion (ppb) of lead. The USEPA action level for lead in drinking water is 15.0 ppb for PSW. The USEPA document titled "Lead in Drinking Water at Schools and Child Care Facilities" last updated November 9, 2015 identifies an action level for drinking water collected from a plumbing fixture as 20.0 ppb. Eighty-three (83) samples collected from the selected locations at the Boone Trail Elementary reported sample results which were less than the action level. This information can be found under the National Primary Drinking Water Regulations provided by the EPA, CFR 2010 Title 40. (See Appendix A and B for Sample Results) The Missouri Senate Bill 1075 require potable plumbing fixtures to be less than 5.0 ppb, the levels area above 5 ppb, then action shall be necessary to filter the water from the fixture or clean/repair/replace the fixture and retest until the levels are reported below 5 ppb. Four (4) samples collected from the selected locations at the Boone Trail Elementary reported sample results which are above 5 ppb (See Appendix A and B for Sample Results)

The following results are greater than the 5 ppb requirements under Senate Bill 681.

Sample ID 09A Kitchen- Dishwashing Sink (Right) – Sink	(6.0 ppb)
Sample ID 12A Kitchen- Middle 2-Bay (Left) – Sink	(8.2 ppb)
Sample ID 15A Kitchen- Near Freezer (Left) – Sink	(6.0 ppb)
Sample ID 16A Kitchen- Near Freezer (Right) – Sink	(6.5 ppb)

At this time all water sources testing at 15 ppb or above should be removed from service. These sources are subject to additional maintenance activities and response actions prior to use. Before being put back in service, J.S. Held recommends these sources be re-tested to confirm compliance with acceptable levels. In addition, all sources will be subject to an ongoing maintenance program and re-testing at appropriate intervals. Any samples reported over 5 ppb should be re-sampled on an annual basis at a minimum.

J.S. Held recommends that all water sources run for at least thirty seconds prior to use as recommended by the USEPA.

J.S. Held is pleased to provide this information to Wentzville R-IV School District and we appreciate the opportunity to provide quality environmental consulting services. Please call us at (618) 343-3590 if you have any questions or to arrange a meeting to discuss.

Sincerely, J.S. Held, LLC

Jim Uasitis

Jim Yasitis

Vice President of Environmental Health & Safety

APPENDIX A SAMPLE LOCATIONS & RESULTS

TABLE 1

Drinking Water Sampling for Lead Content Wentzville R-IV School District Boone Trail Elementary School

Sampled: October 25, 2023

Samp	ole ID Location	Water Source	Results (ppb)					
01A	South Restrooms between 213,110(Right)	Fountain	<1.0					
01B	South Restrooms between 213,110(Right)	Fountain	<1.0					
02A	South Restrooms between 213,110 (Left)	Fountain	<1.0					
02B	South Restrooms between 213,110 (Left)	Fountain	<1.0					
03A	North Restrooms between 213,110 (Left)	Fountain	<1.0					
03B	North Restrooms between 213,110 (Left)	Fountain	<1.0					
04A	North Restrooms between 213,110 (Right)	Fountain	<1.0					
04B	North Restrooms between 213,110 (Right)	Fountain	<1.0					
05A	Near Room 100 (Left)	Fountain	<1.0					
05B	Near Room 100 (Left)	Fountain	<1.0					
06A	Near Room 100 (Right)	Fountain	<1.0					
06B	Near Room 100 (Right)	Fountain	<1.0					
07A	Nurse's Office	Sink	2.1					
07B	Nurse's Office	Sink	<1.0					
08A	Kitchen- Dishwashing Sink (Far Right)	Sink	2.0					
08B	Kitchen- Dishwashing Sink (Far Right)	Sink	<1.0					
09A	Kitchen- Dishwashing Sink (Right)	Sink	6.0					
09B	Kitchen- Dishwashing Sink (Right)	Sink	<1.0					
10A	Kitchen- Dishwashing Sink (Middle)	Sink	2.2					
10B	Kitchen- Dishwashing Sink (Middle)	Sink	<1.0					
11A	Kitchen- Dishwashing Sink (Left)	Sink	4.6					
11B	Kitchen- Dishwashing Sink (Left)	Sink	<1.0					
12A	Kitchen- Middle 2-Bay (Left)	Sink	8.2					
12B	Kitchen- Middle 2-Bay (Left)	Sink	<1.0					
13A	Kitchen- Middle 2-Bay (Right)	Sink	2.2					
13B	Kitchen- Middle 2-Bay (Right)	Sink	<1.0					
14A	Kitchen- Pot Filler	Sink	2.2					
14B	Kitchen- Pot Filler	Sink	2.3					
15A	Kitchen- Near Freezer (Left)	Sink	6.0					
15B	Kitchen- Near Freezer (Left)	Sink	<1.0					
16A	Kitchen- Near Freezer (Right)	Sink	6.5					
16B	Kitchen- Near Freezer (Right)	Sink	<1.0					
17	Kitchen – Ice Machine	Ice Machine	<1.0					
18A	Near Gym (Left)	Fountain	<1.0					
18B	Near Gym (Left)	Fountain	<1.0					

Samp	le ID Location	Water Source	Results (ppb)
19A	Near Gym (Right)	Fountain	<1.0
19B	Near Gym (Right)	Fountain	<1.0
20A	Room 304	Sink	3.2
20B	Room 304	Sink	<1.0
21	Room 304- Ice Machine	Ice Machine	<1.0
22A	Near Restroom 402 (Left)	Fountain	<1.0
22B	Near Restroom 402 (Left)	Fountain	<1.0
23A	Near Restroom 402 (Right)	Fountain	<1.0
23B	Near Restroom 402 (Right)	Fountain	<1.0
24A	Near Room 518 (Left)	Fountain	<1.0
24B	Near Room 518 (Left)	Fountain	<1.0
25A	Near Room 518 (Right)	Fountain	<1.0
25B	Near Room 518 (Right)	Fountain	<1.0
26A	Room 403B- Library	Sink	<1.0
26B	Room 403B- Library	Sink	<1.0
27A	Near Room K8 (Right)	Fountain	<1.0
27B	Near Room K8 (Right)	Fountain	<1.0
28A	Near Room K8 (Left)	Fountain	<1.0
28B	Near Room K8 (Left)	Fountain	<1.0
29A	Near Room K7 (Right)	Fountain	<1.0
29B	Near Room K7 (Right)	Fountain	<1.0
30A	Near Room K7 (Left)	Fountain	<1.0
30B	Near Room K7 (Left)	Fountain	<1.0
31A	Room 115	Sink	<1.0
31B	Room 115	Sink	<1.0
32	Room 115- Ice Machine	Ice Machine	<1.0
33A	Near Room K4 (Right)	Fountain	<1.0
33B	Near Room K4 (Right)	Fountain	<1.0
34A	Near Room K4 (Left)	Fountain	<1.0
34B	Near Room K4 (Left)	Fountain	<1.0
35A	Near Room K1 (Right)	Fountain	<1.0
35B	Near Room K1 (Right)	Fountain	<1.0
36A	Near Room K1 (Left)	Fountain	<1.0
36B	Near Room K1 (Left)	Fountain	<1.0
37A	Room K1	Sink	<1.0
37B	Room K1	Sink	<1.0
38A	Room K2	Sink	<1.0
38B	Room K2	Sink	<1.0
39A	Room K3	Sink	<1.0
39B	Room K3	Sink	<1.0
40A	Room K4	Sink	<1.0
40B	Room K4	Sink	<1.0
41A	Room K6	Sink	<1.0
41B	Room K6	Sink	<1.0

Samp	le ID Location	Water Source	Results (ppb)
42A	Room K7	Sink	<1.0
42B	Room K7	Sink	<1.0
43A	Room K8	Sink	<1.0
43B	Room K8	Sink	<1.0

Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.
chective.


Water source is 5-19.9 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum.

Sample Legend

#####<mark></mark>

"A" = First Draw

[&]quot;B" = Second Draw



APPENDIX B LABORATORY ANALYSIS



November 06, 2023

Jim Yasitis
Environmental Consultants, LLC
#6 Meadow Heights Professional Park
Collinsville, IL 62234

TEL: (618) 343-3590 FAX: (618) 343-3597

TNI TNI TNI TNI TNI

WorkOrder: 23101977

Illinois 100226 Kansas E-10374 Louisiana 05002 Louisiana 05003 Oklahoma 9978

RE: Wentzville SD Water Sampling 231000104 Boone

Trail

Dear Jim Yasitis:

TEKLAB, INC received 33 samples on 10/25/2023 8:32:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marvin L. Darling Project Manager

(618)344-1004 ex 41

mdarling@teklabinc.com

Mowin L. Darling I



Report Contents

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
 - DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
 - DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Qualifiers

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Cooler Receipt Temp: NA °C

Locations

	Collinsville		Springfield	Kansas City						
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road					
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214					
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998					
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998					
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com					
	Collinsville Air		Chicago							
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.							
	Collinsville, IL 62234-7425		Downers Grove, IL 60515							
Phone	(618) 344-1004	Phone	(630) 324-6855							
Fax	(618) 344-1005	Fax								
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com							



Accreditations

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

http://www.teklabinc.com/

Report Date: 06-Nov-23

Client: Environmental Consultants, LLC Work Order: 23101977

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	4, 200.8 R5.4, META	LS BY ICPMS (TOTAL)						
Lead	,	` ,						
23101977-001	A 27A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:37	10/25/2023 3:00
23101977-002	A 27B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:41	10/25/2023 3:00
23101977-003	A 28A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:45	10/25/2023 3:00
23101977-004	A 28B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:10	10/25/2023 3:00
23101977-005	6A 29A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:14	10/25/2023 3:00
23101977-006	6A 29B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:18	10/25/2023 3:00
23101977-007	'A 30A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:22	10/25/2023 3:00
23101977-008	A 30B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:26	10/25/2023 3:00
23101977-009	A 31A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:30	10/25/2023 3:00
23101977-010	A 31B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:34	10/25/2023 3:00
23101977-011	A 32	NELAP	1.0	< 1.0	μg/L	5	11/02/2023 16:49	10/25/2023 3:00
23101977-012	A 33A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:32	10/25/2023 3:00
23101977-013	A 33B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:36	10/25/2023 3:00
23101977-014	A 34A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:40	10/25/2023 3:00
23101977-015	6A 34B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:44	10/25/2023 3:00
23101977-016	6A 35A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:00	10/25/2023 3:00
23101977-017	'A 35B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:48	10/25/2023 3:00
23101977-018	36A 36A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:52	10/25/2023 3:00
23101977-019	A 36B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 10:56	10/25/2023 3:00
23101977-020	A 37A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:28	10/25/2023 3:00
23101977-021	A 37B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:32	10/25/2023 3:00
23101977-022	A 38A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:36	10/25/2023 3:00
23101977-023	A 38B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:40	10/25/2023 3:00
23101977-024	A 39A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:44	10/25/2023 3:00
23101977-025	A 39B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:48	10/25/2023 3:00
23101977-026	6A 40A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:56	10/25/2023 3:00
23101977-027	'A 40B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:52	10/25/2023 3:00
23101977-028	8A 41A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:25	10/25/2023 3:00
23101977-029	A 41B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:29	10/25/2023 3:00
23101977-030	A 42A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:33	10/25/2023 3:00
23101977-031	A 42B	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 16:17	10/25/2023 3:00
23101977-032	A 43A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 16:13	10/25/2023 3:00
23101977-033	6A 43B	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 16:41	10/25/2023 3:00



Receiving Check List

http://www.teklabinc.com/

Work Order: 23101977 Client: Environmental Consultants, LLC Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23 Carrier: Devon Rathbun Received By: HAW Elizabeth a Hurley Completed by: Reviewed by: On: On: 26-Oct-23 27-Oct-23 Elizabeth A. Hurley Ellie Hopkins Extra pages included Pages to follow: Chain of custody 3 Shipping container/cooler in good condition? Yes **✓** No 🗔 Not Present Temp °C NA Type of thermal preservation? **~** Ice _ Blue Ice None Dry Ice Chain of custody present? **~** No L Yes Chain of custody signed when relinquished and received? **~** Yes No L **~** Chain of custody agrees with sample labels? No 🗀 Yes **~** Samples in proper container/bottle? Yes No 🗀 **V** Sample containers intact? Yes No Sufficient sample volume for indicated test? Yes No **~** No \square All samples received within holding time? Yes NA 🗸 Field Lab 🗌 Reported field parameters measured: Yes 🗸 No \square Container/Temp Blank temperature in compliance? When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected. No VOA vials ✓ Water - at least one vial per sample has zero headspace? Yes 🗌 No 🗀 No TOX containers Water - TOX containers have zero headspace? Yes No 🗌 Yes 🗹 No 🗌 Water - pH acceptable upon receipt? Yes NA 🗸 NPDES/CWA TCN interferences checked/treated in the field? No 🗀

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

pg. 6 of 9 Work Order * 2010/174

									e-		-																
Client:	J.S. Held									34M)	ples	5 (D)	n: i		CQ.	O BN	ie lo	```	X M	lce		_	IX.	- GP			
Address:	6 Meadow Heig	hts Prof Par	<u>k</u>)res	ery.	ed	1807	٨.	Lab	O	Fich	j.	16	OR L	AB	USE.	OML	ľ			
City / State / Zi	p: Collinsville, ILE	(2234								.ab	Noi	明念,															
Contact: Jin	n Vasitis	Phone:	618-3	43-	359	0																					
E-Mail: jame	s. yasitis@jsheld.co	n Fax:	618-3	43-	3597	7				30m				7.		Εæ				~							
	s known to be involved in liti		urcharge	will	apply.		es [I No	o 🐰	D	ソじ	W.	C	6.*		ı— ıc	Micr	707	*	<i>-</i> 26	LU	VI.					
 Are there any req 	Are these samples known to be hazardous? Yes Mo Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in comment section. Yes No					e	P/ea	gel	rc	Po	rt	řÆ	ppl	1.													
Project	Project Name / Number Sample Collector's Name Ventzuille 5D Water Sampling Brad Finds								MA'	TR!	X			- Andrews	INL	dica	TE A	ANAL	_YSI	SRE	QUE	STE	D				
231000104	Water Sampling	Brad F.	risch								Jej.	- Carrie and American) Department				(Allego Allego	and and an analysis									
Results I	Requested Bi	lling Instructio	ons #	and	Туре	of (Conta	ine	rs		Water	o contraction of the contraction		0	(ma)		S. C. Control	A COLUMN COMPANY		of the second							
	Day (100% Surcharge) 3 Day (50% Surcharge)	•	2	g y		<i>a</i>	5	Q Q		6	Kimg	Towns (Circle)	වල	Was) ~		W. C.	and in control of the	, and the second	-							
L	Sample Identification	Date Higgs Com		HNO3	NaOH	220	Meon	NaHSO4	Other	Water	Orinking	Soil	Sludge	Sp. Waste	eau	and the second		Andrew									
harries and the second	}	10.25.23 3:		3 <u>프</u> (2 =		5 2	6	0		X	-		-	<u>~</u>		_										
13 01117-00		10.33.33			┼┼	-	-				X		•		$\frac{\alpha}{\gamma}$				-		·						
	27B		1 3		╁╋	-					-				1							-					
	184		}		\dashv	_	-				$\frac{\chi}{\chi}$				X							-				-	
	28B.		1 18				-			ļ	إحسا				X			}				-				-	-
000000000000000000000000000000000000000	1294					_ _		ļ			X				X						,				-	 	-
	293		-		 	_	_	<u></u>			X				大	<u> </u>						 			-	-	-
100000000000000000000000000000000000000	30 A	<u> </u>				_				J	X		ļ		χ							-		ļ. -		ļ	ļ
008	30 B			X							1/2				X				ganomico.	TO THE REAL PROPERTY.			-			<u> </u>	
009	3(A			κ							x				χ												
o jo	31B			7							X				χ											or constitution	
· · . F	Relinquished By	<u>'</u>		Date	/Tin	ne		<u> </u>	<u> </u>	<u>"</u>	4			·	Rec	ived	By			`			Daí	te / T	ime		
Den	n Roxison	10,	JS. 2	<i>02</i> 3						9	100		\sqrt{Q}	_	We						10/	125	/23		08	32	
													-	we with the same			DU-0			ageneries P. Garager Service		Market Branch and Barrier				······································	
																		itmin.									
																								-			

pg. Z of 9 Work Order % 231017710

Client: J. 5. Helk			.)		如的低	Nes 的	n: L	1 10	6 L		CG	21 11/10	tice :				Ç.		
Address: 6 Meadow Heig	phts Prof Park			P	rese	rved	in:	Z.L	āΔ	Ofi	ald	E	or L	16 N	SE O	MLY			
City State Zip: Collinsville, IL	6.2234				ab h	loins													
Contact: Jim Vasitis	Phone: 6/2	8-343-39	590																
E-Mail: james. yasitis@jsheld.co.	m Fax: 6/	8-343-35	97			nenis		7>-a	, 1	_ = tem.	era a		C						
 Are these samples known to be involved in lit Are these samples known to be hazardous? Are there any required reporting limits to be n limits in comment section. 图 Yes □ No 	□ Yes ⊠ No		•	No						ppb.									
Project Name / Number	Sample C	ollector's	Name		N	IATR	IX			11	NDIC/	ite A	ANAL'	ysis	REQ	<u>ues</u> :	<u>TED</u>		
Wentzuille SD Water Sampling 231000104	Brad Frise	h			-	Water		-		A TOTAL PORTING				Andreas (in particular					
Results Requested B	illing Instructions		pe of Contain			7		2	(DM)		and a second		MINISTER	La paración que	a transport		and the state of t		.
☑ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)	·	UNPRES MNO.	HCL MeOH	500	Water	Drinking Soil	Sludge		ead		Electrical designation of the second	a Ciling and the Community		A.A. Tarabili California i	Seattle d'on Lerie gene	Transfer of the state of the st	A and the second second		
Lab Use Only Sample Identification	Date/Time Sampled		E Z Z	Nario Other	8	ā j ŭ	S	N	3		-				3				
2310 M112011 32	10.25.23 3:00	X				X	1		X										
nia 334		χ				X			X			e)							
813 33 B		X				X			X										
014 34A		K				X	1		Y								·		
DIS 348		. V				X			X					ŕ					
016 35A		χ				r			x							<u></u>			
017 35 B		χ				χl			χ										
018 36 A		X				k -		-	χ							·			·
019 368		K				r		·	χ							- Aller Market			
020 37A		X				X			X								.]		
· · · Relinquished By		Date /	Time	لسبساسي				F	lecei	ved By					[Jate	/Tim	ie	
Deven. Rathbin.	10.25				Ø	0	L	N)مر		elineliteris es en el melle e			1012	17/2	3_	0	83 <i>a</i>	λ
·		October Common C	NEW YEAR OLD THE STREET STREET STREET	التكاوية والمحالة والمحالة					-	- AND THE PROPERTY OF THE PROP					, ,				·
				رىدىن دىرو دوروسىيە.					to the state of th			ranga dilirandirandiran							

pg. 8 of 9 Work Order # 23497777

Client: J. S. Held							200	plles	ø'n	ı, E	l le	1 0 1	aule C	lce	o N	o Ice				PC			
Address: 6 Meadow Heights 1 City State Zip: Collinsuille, IL 622	Prof Park				_	Į į	res	arve	ct i	n: l	11	alo:	Of	rd.	Į.	OR I	LAB	USE	OML	Ĺ			
City State Zip: <u>Collinsville, IL 622</u>	34				_		ald i	Voja	6														
Contact: Jim Yasitis	Phone: 6/8-	343-3	3590		_																		
Contact: Jim Vasitis E-Mail: james. yasitis@jsheld.com	Fax: 6/8	343-3	597					mer			77°C), j	Œ iem	£11-4		ζ,	/.	434					
Are these samples known to be involved in litigation Are these samples known to be hazardous? 口 Yes Are there any required reporting limits to be met on limits in comment section. 图 Yes 口 No	No W No the requested ana	- lysis? If	yes, plo	ease (-	. 8							ppb.										
Project Name / Number	Sample Col	ector's	s Nam	e ·				MAT	RI	K			***************************************	INDIC	ate.	ANA	Lysi	SRE	QUE	STE	2	7	
Wentzuille SD Water Sampling 2 231000104	Brad Frisch						December of the Control of the Contr	ater	acting of the particularies.	Company of the Party of the Par	•	~		ACCIONANCION ACCIONA		(Dog-many)				-	a. Mayong direction of the		
Results Requested Billing Standard 1-2 Day (100% Surcharge)		# and T						Drinking Water			216	(DM)								alu profesiones	conjection plane (the		
□ Other □ 3 Day (50% Surcharge)		UNPRES HNO:	H 0		E S	19	Water	imkin	100	Sludge	Sp. waste	ead								Annual State of State	Street Street Street		
Lab Use Only Sample Identification Date	/Time Sampled	SE	Na H26	2	S Z	Š	\$	ā	ğ	Ø e	8	7											
13 0141-021 378 (o.	25-23 3:00	X						X		\cdot		X											
014 38A		χ						X	Chiefermolecus			χ			[······································	·
113 38 E		χ						X				X										agentaria properties	
D)4 39H		8						X				γ											
NT 39B · '		γ						X				X										والمرابعة	
0) 40 A		[γ]						r				አ									,	~~,,,,,,,,,,	
DN 40B		$ \chi $						x				K _								,		_	
078 41A		X						λ-				χ											
08 41B		X						γ			·	χ											
D30 42A		K						X				χ											
Relinquished By			/Time			- Cortece No.						Design Market	ived By	1			<u></u>	والم معاوم سروسي		e / Ti			
Devon Rathlan.	10.25.	<u> </u>	· · · · · · · · · · · · · · · · · · ·		minar-reside		<u> </u>	ta	201	_	W)	<u>~</u>		***************************************	ACCOUNT OF THE PARTY NAMED IN COLUMN		10/	27/	<u>33</u>	0	<u>83</u> 2	<u>} </u>	
							_			EDOWN PALEDERS	مرينياري مومارينياري		CTIPLE THE POST OF PARTY			article and a second second							
		·					_			********	-	Digweller Lawy Cold.	Managerity was a second state of the				 						
							!				-												

og. 9 of 9 Work Order # 310 1977

Client: J. S. Held											D Blual						eC:		
Address: 6 Meadow Heig	hts Prof Park					Pres	er.	ed in	: El	Lab	Ofi	eld .	Ę	jr lae) USE	OML)	<u>r</u>		
City State Zip: Collinsuille, IL 6	5.2234			·····		Lab	P143.6	98X											
Contact: Jim Vasitis	Phone: _6/3	- 343-	3590	·															
E-Mail: james. yasitis@jsheld.com	<u>n</u> Fax: <u>6/8</u>	-343-	3597			Con			7,	16 I	Eiemi			Ć.,	.071 2				
PAre these samples known to be involved in liting Are these samples known to be hazardous? If Are there any required reporting limits to be making limits to be making the comment section. If Yes	□ Yes Mo			•							296.	78 70	7	A. L.	A)				
Project Name / Number	Sample Co	llecto	's Nan	ne			MA	TRIX				VDIC.	ate <u>a</u>	NALYS	SIS RE	QUE	stel) ,	
Wentzuille SD Water Sampling 231000104	Brad Frisch	h					íter.	-	200	(
Results Requested Bi	lling Instructions			f Conta			y Water		9	(md)				v)) p. stansferage kan					
☑ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		E S	TÃ		Ö ,	ier.	Orinking		Sp. Waste	~		and the second		C) C) Company	gome, restanción de la companya de l		-		
Lab Use Only Sample Identification	Date/Time Sampled	UNPRES	OF Z	HOH Meon	Nari	Mater	Pi	Soil	S.	Lea				Q			Arraman de la composição de la composiçã		
13101477-08 42B	10.25.23 3:00	X	1.				X			X		-					- Indiana		
032 43A		Īχ	11			-	X		_	X			157						
112 43 B		$\hat{\chi}$	1				χ			X									
		r					X		-	Y									
r e e e e e e e e e e e e e e e e e e e		·V					K			X									
		X					γ			x									
		λ					lχ			X									
		X					λ.			X								·	
		K					X			χ		-		The state of the s			·		
		X					X			X									
Relinquished By		Date	· / Tim	<u></u>		7		<u></u>		Rec	eived By	-1				Date	e / Ti	me	
Devon. Rathin	10.25.	202	3			<u> </u>	14/1	~dh		<u> </u>				110	1251	03	09	336	λ
		With Company to a company									**************************************		الإنجامية المستعمدة						
											<u> الموادد ويون الموادد ا</u>							<u></u>	
The individual signing this agreement on beh	nalf of client acknowled	iges tha	at he/sh	e has re	ad and	lund	arcta	nda 61	h- 4		•								

TABLE 1

Drinking Water Sampling for Lead Content Wentzville R-IV School District Boone Trail Elementary School

Sampled: October 25, 2023

O1A South Restrooms between 213,110(Right) Fountain O1B South Restrooms between 213,110 (Left) Fountain O2A South Restrooms between 213,110 (Left) Fountain O3A North Restrooms between 213,110 (Left) Fountain O3A North Restrooms between 213,110 (Left) Fountain O3A North Restrooms between 213,110 (Left) Fountain O4A North Restrooms between 213,110 (Right) O4A North Restrooms between 213,110 (Right) O4B North Restrooms between 213,110 (Right) O5A Near Room 100 (Left) Fountain O5A Near Room 100 (Left) Fountain O5A Near Room 100 (Right) Fountain O6B Near Room 100 (Right) Fountain O6B Near Room 100 (Right) Fountain O7A Nurse's Office Sink O7B Nurse's Office Sink O8A Kitchen-Dishwashing Sink (Far Right) Sink O8B Kitchen-Dishwashing Sink (Right) Sink O9B Kitchen-Dishwashing Sink (Right) Sink O9B Kitchen-Dishwashing Sink (Right) Sink O1B Kitchen-Dishwashing Sink (Middle) Sink O1B Kitchen-Dishwashing Sink (Left) Sink O1B Kitchen-Dishwashing Sink (Left) Sink O1B Kitchen-Dishwashing Sink (Left) Sink O1B Kitchen-Middle 2-Bay (Left) Sink O1B Kitchen-Middle 2-Bay (Right) Sink O1B Kitchen-Near Freezer (Left) Sink O1B Kitchen-Near Freezer (Right) Si	Samp	le ID Location	Water Source	Results (ppb)
O2A South Restrooms between 213,110 (Left) O2B South Restrooms between 213,110 (Left) Fountain O3A North Restrooms between 213,110 (Left) O4A North Restrooms between 213,110 (Right) O4B North Restrooms between 213,110 (Right) O4B North Restrooms between 213,110 (Right) O4B North Restrooms between 213,110 (Right) O5A Near Room 100 (Left) O5A Near Room 100 (Left) O6A Near Room 100 (Right) O6B Near Room 100 (Right) O7A Nurse's Office O7B Nurse's Office O8A Kitchen- Dishwashing Sink (Far Right) O9A Kitchen- Dishwashing Sink (Far Right) O9A Kitchen- Dishwashing Sink (Right) O9B Kitchen- Dishwashing Sink (Right) O9B Kitchen- Dishwashing Sink (Middle) O1A Kitchen- Dishwashing Sink (Middle) O1A Kitchen- Dishwashing Sink (Middle) O2B Kitchen- Dishwashing Sink (Middle) O3B Kitchen- Dishwashing Sink (Left) O3B Kitchen- Middle 2-Bay (Left) O3B Kitchen- Middle 2-Bay (Right) O3B Kitchen- Middle 2-Bay (Right) O3B Kitchen- Near Freezer (Left) O3B Kitchen- Near Freezer (Right) O3B Kitchen- N	01A	South Restrooms between 213,110(Right)	Fountain	
O2B South Restrooms between 213,110 (Left) Fountain O3A North Restrooms between 213,110 (Left) Fountain O3B North Restrooms between 213,110 (Left) Fountain O4A North Restrooms between 213,110 (Right) O4B North Restrooms between 213,110 (Right) Fountain O5A Near Room 100 (Left) Fountain O5A Near Room 100 (Left) Fountain O6B Near Room 100 (Right) Fountain O6B Near Room 100 (Right) Fountain O6B Nurse's Office Sink O7B Nurse's Office Sink O8A Kitchen- Dishwashing Sink (Far Right) Sink O8B Kitchen- Dishwashing Sink (Far Right) Sink O9A Kitchen- Dishwashing Sink (Right) Sink O9B Kitchen- Dishwashing Sink (Right) Sink O8B Kitchen- Dishwashing Sink (Right) Sink O9B Kitchen- Dishwashing Sink (Right) Sink O8B Kitchen- Dishwashing Sink (Left) Sink O8B Kitchen- Middle 2-Bay (Left) Sink O8B Kitchen- Middle 2-Bay (Right) Sink O8B Kitchen- Near Freezer (Left) Sink O8B Kitchen- Near Freezer (Left) Sink O8B Kitchen- Near Freezer (Left) Sink O8B Kitchen- Near Freezer (Right) Sink O8B Kitchen	01B	South Restrooms between 213,110(Right)	Fountain	
03ANorth Restrooms between 213,110 (Left)Fountain03BNorth Restrooms between 213,110 (Right)Fountain04ANorth Restrooms between 213,110 (Right)Fountain04BNorth Restrooms between 213,110 (Right)Fountain05ANear Room 100 (Left)Fountain05BNear Room 100 (Right)Fountain06ANear Room 100 (Right)Fountain07BNurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Middle)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Left)Sink16BKitchen- Near Freezer (Right)Sink16CKitchen- Near Freezer (Right)Sink16CKitchen- Near Freezer (Right)Sink16CKitchen- Near Freezer (Right)Sink17Kitchen- Near Freezer (Right)Sink18Near Gym (Left)Sink <td>02A</td> <td>South Restrooms between 213,110 (Left)</td> <td>Fountain</td> <td></td>	02A	South Restrooms between 213,110 (Left)	Fountain	
03BNorth Restrooms between 213,110 (Left)Fountain04ANorth Restrooms between 213,110 (Right)Fountain04BNorth Restrooms between 213,110 (Right)Fountain05ANear Room 100 (Left)Fountain05BNear Room 100 (Right)Fountain06ANear Room 100 (Right)Fountain06BNear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Right)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Left)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink17Kitchen- Near Freezer (Right)Sink18ANear Gym (Left)Fountain	02B	South Restrooms between 213,110 (Left)	Fountain	
04ANorth Restrooms between 213,110 (Right)Fountain04BNorth Restrooms between 213,110 (Right)Fountain05ANear Room 100 (Left)Fountain05BNear Room 100 (Right)Fountain06ANear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Far Right)Sink09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Near Freezer (Right)Sink18ANear Gym (Left)Fountain	03A	North Restrooms between 213,110 (Left)	Fountain	
04BNorth Restrooms between 213,110 (Right)Fountain05ANear Room 100 (Left)Fountain05BNear Room 100 (Right)Fountain06ANear Room 100 (Right)Fountain06BNear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink15BKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink17Kitchen - Near Freezer (Right)Sink17Kitchen - Near Freezer (Right)Sink18ANear Gym (Left)Fountain	03B	North Restrooms between 213,110 (Left)	Fountain	
05A Near Room 100 (Left) Fountain 05B Near Room 100 (Left) Fountain 06A Near Room 100 (Right) Fountain 06B Near Room 100 (Right) Fountain 06B Near Room 100 (Right) Fountain 07A Nurse's Office Sink 07B Nurse's Office Sink 08A Kitchen- Dishwashing Sink (Far Right) Sink 08B Kitchen- Dishwashing Sink (Far Right) Sink 09A Kitchen- Dishwashing Sink (Right) Sink 09A Kitchen- Dishwashing Sink (Right) Sink 10A Kitchen- Dishwashing Sink (Middle) Sink 11A Kitchen- Dishwashing Sink (Middle) Sink 11B Kitchen- Dishwashing Sink (Left) Sink 11B Kitchen- Dishwashing Sink (Left) Sink 12A Kitchen- Middle 2-Bay (Left) Sink 12B Kitchen- Middle 2-Bay (Left) Sink 13A Kitchen- Middle 2-Bay (Right) Sink 13B Kitchen- Middle 2-Bay (Right) Sink 14A Kitchen- Pot Filler Sink 14A Kitchen- Pot Filler Sink 14B Kitchen- Near Freezer (Left) Sink 15B Kitchen- Near Freezer (Left) Sink 16B Kitchen- Near Freezer (Right) Sink 17 Kitchen - Ice Machine Ice Machine 18A Near Gym (Left) Fountain	04A	North Restrooms between 213,110 (Right)	Fountain	
05BNear Room 100 (Left)Fountain06ANear Room 100 (Right)Fountain06BNear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Far Right)Sink09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Left)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	04B	North Restrooms between 213,110 (Right)	Fountain	
06ANear Room 100 (Right)Fountain06BNear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15AKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	05A	Near Room 100 (Left)	Fountain	
06BNear Room 100 (Right)Fountain07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	05B	Near Room 100 (Left)	Fountain	
07ANurse's OfficeSink07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10BKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	06A	Near Room 100 (Right)	Fountain	
07BNurse's OfficeSink08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Far Right)Sink09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink11BKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	06B	Near Room 100 (Right)	Fountain	
08AKitchen- Dishwashing Sink (Far Right)Sink08BKitchen- Dishwashing Sink (Far Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10BKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Left)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain	07A	Nurse's Office	Sink	
08BKitchen- Dishwashing Sink (Far Right)Sink09AKitchen- Dishwashing Sink (Right)Sink10BKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Left)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen - Ice MachineIce Machine18ANear Gym (Left)Fountain	07B	Nurse's Office	Sink	
09AKitchen- Dishwashing Sink (Right)Sink09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink15AKitchen- Pot FillerSink15BKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain	08A	Kitchen- Dishwashing Sink (Far Right)	Sink	
09BKitchen- Dishwashing Sink (Right)Sink10AKitchen- Dishwashing Sink (Middle)Sink10BKitchen- Dishwashing Sink (Middle)Sink11AKitchen- Dishwashing Sink (Left)Sink11BKitchen- Dishwashing Sink (Left)Sink12AKitchen- Middle 2-Bay (Left)Sink12BKitchen- Middle 2-Bay (Right)Sink13AKitchen- Middle 2-Bay (Right)Sink13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink15AKitchen- Pot FillerSink15BKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Right)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain	08B	Kitchen- Dishwashing Sink (Far Right)	Sink	
10A Kitchen- Dishwashing Sink (Middle) 10B Kitchen- Dishwashing Sink (Middle) 11A Kitchen- Dishwashing Sink (Left) 11B Kitchen- Dishwashing Sink (Left) 11B Kitchen- Dishwashing Sink (Left) 12A Kitchen- Middle 2-Bay (Left) 12B Kitchen- Middle 2-Bay (Left) 13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 14B Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16A Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Sink 10B Sink 11C EMachine 11C Machine 11C Machine 11C Machine 11C Fountain	09A	Kitchen- Dishwashing Sink (Right)	Sink	
10B Kitchen- Dishwashing Sink (Middle) 11A Kitchen- Dishwashing Sink (Left) 11B Kitchen- Dishwashing Sink (Left) 12A Kitchen- Middle 2-Bay (Left) 12B Kitchen- Middle 2-Bay (Left) 13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 15A Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16B Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Sink Sink Sink Sink Sink Sink Sink	09B	Kitchen- Dishwashing Sink (Right)	Sink	
11A Kitchen- Dishwashing Sink (Left) 11B Kitchen- Dishwashing Sink (Left) 12A Kitchen- Middle 2-Bay (Left) 12B Kitchen- Middle 2-Bay (Left) 13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 14B Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16A Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Fountain	10A	Kitchen- Dishwashing Sink (Middle)	Sink	
11B Kitchen- Dishwashing Sink (Left) Sink 12A Kitchen- Middle 2-Bay (Left) Sink 12B Kitchen- Middle 2-Bay (Left) Sink 13A Kitchen- Middle 2-Bay (Right) Sink 13B Kitchen- Middle 2-Bay (Right) Sink 14A Kitchen- Pot Filler Sink 14B Kitchen- Pot Filler Sink 15A Kitchen- Near Freezer (Left) Sink 15B Kitchen- Near Freezer (Left) Sink 16A Kitchen- Near Freezer (Right) Sink 16B Kitchen- Near Freezer (Right) Sink 16B Kitchen- Near Freezer (Right) Sink 17 Kitchen – Ice Machine Ice Machine 18A Near Gym (Left) Fountain	10B	Kitchen- Dishwashing Sink (Middle)	Sink	
12A Kitchen- Middle 2-Bay (Left) 12B Kitchen- Middle 2-Bay (Left) 13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 14B Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16A Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Sink Sink Sink Sink Sink Sink Sink	11 A	Kitchen- Dishwashing Sink (Left)	Sink	
12B Kitchen- Middle 2-Bay (Left) 13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 14B Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16A Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Sink Sink Sink Sink Sink Sink Sink	11B	Kitchen- Dishwashing Sink (Left)	Sink	
13A Kitchen- Middle 2-Bay (Right) 13B Kitchen- Middle 2-Bay (Right) 14A Kitchen- Pot Filler 14B Kitchen- Pot Filler 15A Kitchen- Near Freezer (Left) 15B Kitchen- Near Freezer (Left) 16A Kitchen- Near Freezer (Right) 16B Kitchen- Near Freezer (Right) 17 Kitchen – Ice Machine 18A Near Gym (Left) Sink Sink Ice Machine Fountain		Kitchen- Middle 2-Bay (Left)	Sink	
13BKitchen- Middle 2-Bay (Right)Sink14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain	12B	Kitchen- Middle 2-Bay (Left)	Sink	
14AKitchen- Pot FillerSink14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain		Kitchen- Middle 2-Bay (Right)	Sink	
14BKitchen- Pot FillerSink15AKitchen- Near Freezer (Left)Sink15BKitchen- Near Freezer (Left)Sink16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain		Kitchen- Middle 2-Bay (Right)	Sink	
15A Kitchen- Near Freezer (Left) Sink Sink Kitchen- Near Freezer (Left) Kitchen- Near Freezer (Right) Kitchen- Near Freezer (Right) Kitchen- Near Freezer (Right) Kitchen- Ice Machine Near Gym (Left) Sink Ice Machine Fountain		Kitchen- Pot Filler	Sink	
15B Kitchen- Near Freezer (Left) Sink 16A Kitchen- Near Freezer (Right) Sink 16B Kitchen- Near Freezer (Right) Sink 17 Kitchen – Ice Machine Ice Machine 18A Near Gym (Left) Fountain		Kitchen- Pot Filler	Sink	
16AKitchen- Near Freezer (Right)Sink16BKitchen- Near Freezer (Right)Sink17Kitchen – Ice MachineIce Machine18ANear Gym (Left)Fountain		Kitchen- Near Freezer (Left)	Sink	
16B Kitchen- Near Freezer (Right) Sink 17 Kitchen – Ice Machine Ice Machine 18A Near Gym (Left) Fountain	15B	Kitchen- Near Freezer (Left)	Sink	
17 Kitchen – Ice Machine Ice Machine 18A Near Gym (Left) Fountain	16A	Kitchen- Near Freezer (Right)	Sink	
18A Near Gym (Left) Fountain		` U ,		
18B Near Gym (Left) Fountain		· · · · · · · · · · · · · · · · · · ·		
	18B	Near Gym (Left)	Fountain	

Samp	ole ID Location	Water Source	Results (ppb)
19A	Near Gym (Right)	Fountain	
19B	Near Gym (Right)	Fountain	
20A	Room 304	Sink	
20B	Room 304	Sink	
21	Room 304- Ice Machine	Ice Machine	
22A	Near Restroom 402 (Left)	Fountain	
22B	Near Restroom 402 (Left)	Fountain	
23A	Near Restroom 402 (Right)	Fountain	
23B	Near Restroom 402 (Right)	Fountain	
24A	Near Room 518 (Left)	Fountain	
24B	Near Room 518 (Left)	Fountain	
25A	Near Room 518 (Right)	Fountain	
25B	Near Room 518 (Right)	Fountain	
26A	Room 403B- Library	Sink	
26B	Room 403B- Library	Sink	
27A	Near Room K8 (Right)	Fountain	
27B	Near Room K8 (Right)	Fountain	
28A	Near Room K8 (Left)	Fountain	
28B	Near Room K8 (Left)	Fountain	
29A	Near Room K7 (Right)	Fountain	
29B	Near Room K7 (Right)	Fountain	
30A	Near Room K7 (Left)	Fountain	
30B	Near Room K7 (Left)	Fountain	
31A	Room 115	Sink	
31B	Room 115	Sink	
32	Room 115- Ice Machine	Ice Machine	
33A	Near Room K4 (Right)	Fountain	
33B	Near Room K4 (Right)	Fountain	
34A	Near Room K4 (Left)	Fountain	
34B	Near Room K4 (Left)	Fountain	
35A	Near Room K1 (Right)	Fountain	
35B	Near Room K1 (Right)	Fountain	
36A	Near Room K1 (Left)	Fountain	
36B	Near Room K1 (Left)	Fountain	
37A	Room K1	Sink	
37B	Room K1	Sink	
38A	Room K2	Sink	
38B	Room K2	Sink	
39A	Room K3	Sink Sink	
39B	Room K4	Sink Sink	
40A 40B	Room K4 Room K4	Sink Sink	
40B 41A	Room K4 Room K6	Sink Sink	
41A 41B	Room K6	Sink	
41D	NOUII NU	SHIK	

Samp	le ID Location	Water Source	Results (ppb)
42A	Room K7	Sink	
42B	Room K7	Sink	
43A	Room K8	Sink	
43B	Room K8	Sink	

44444

Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.

#####

Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum

Sample Legend

"A" = First Draw

"B" = Second Draw



November 06, 2023

Jim Yasitis Environmental Consultants, LLC #6 Meadow Heights Professional Park Collinsville, IL 62234

TEL: (618) 343-3590 FAX: (618) 343-3597

Illinois 100226 Kansas E-10374 Louisiana 05002 Louisiana 05003 Oklahoma 9978

RE: Wentzville SD Water Sampling 231000104 Boone WorkOrder: 23101976

Trail

Dear Jim Yasitis:

TEKLAB, INC received 50 samples on 10/25/2023 8:32:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marvin L. Darling Project Manager

(618)344-1004 ex 41

mdarling@teklabinc.com

Mowin L. Darling I



Report Contents

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976
Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
 - DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
 - DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Qualifiers

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Cooler Receipt Temp: NA °C

Locations

Collinsville		Springfield		Kansas City
5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road
Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214
(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998
(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998
jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com
Collinsville Air Chicago				
5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.		
Collinsville, IL 62234-7425		Downers Grove, IL 60515		
(618) 344-1004	Phone	(630) 324-6855		
(618) 344-1005	Fax			
	Email	arenner@teklabinc.com		
	5445 Horseshoe Lake Road Collinsville, IL 62234-7425 (618) 344-1004 (618) 344-1005 jhriley@teklabinc.com Collinsville Air 5445 Horseshoe Lake Road Collinsville, IL 62234-7425 (618) 344-1004	5445 Horseshoe Lake Road Collinsville, IL 62234-7425 (618) 344-1004 (618) 344-1005 jhriley@teklabinc.com Collinsville Air 5445 Horseshoe Lake Road Collinsville, IL 62234-7425 (618) 344-1004 Phone (618) 344-1005 Fax	5445 Horseshoe Lake Road Address 3920 Pintail Dr Collinsville, IL 62234-7425 Springfield, IL 62711-9415 (618) 344-1004 Phone (217) 698-1004 (618) 344-1005 Fax (217) 698-1005 jhriley@teklabinc.com Email KKlostermann@teklabinc.com Collinsville Air Chicago 5445 Horseshoe Lake Road Address 1319 Butterfield Rd. Collinsville, IL 62234-7425 Downers Grove, IL 60515 (618) 344-1004 Phone (630) 324-6855 (618) 344-1005 Fax	5445 Horseshoe Lake Road Address 3920 Pintail Dr Address Collinsville, IL 62234-7425 Springfield, IL 62711-9415 (618) 344-1004 Phone (217) 698-1004 Phone (618) 344-1005 Fax (217) 698-1005 Fax jhriley@teklabinc.com Email KKlostermann@teklabinc.com Email Collinsville Air Chicago 5445 Horseshoe Lake Road Address 1319 Butterfield Rd. Collinsville, IL 62234-7425 Downers Grove, IL 60515 (618) 344-1004 Phone (630) 324-6855 (618) 344-1005 Fax



Accreditations

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

http://www.teklabinc.com/

Report Date: 06-Nov-23

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail

Matrix: DRINKING WATER

Matrix: Dr	Matrix: DRINKING WATER										
Sample ID Clien	t Sample ID Certification	Qual RL	Result	Units	DF	Date Analyzed	Date Collected				
EPA 600 4.1.4, 200.	8 R5.4, METALS BY ICPMS (1	TOTAL)									
Lead	, ,	,									
23101976-001A 01A	NELAP	1.0	< 1.0	μg/L	1	11/01/2023 23:45	10/25/2023 3:00				
23101976-002A 01E	NELAP	1.0	< 1.0	μg/L	1	11/01/2023 23:49	10/25/2023 3:00				
23101976-003A 02A	NELAP	1.0	< 1.0	μg/L	1	11/01/2023 23:54	10/25/2023 3:00				
23101976-004A 02E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:11	10/25/2023 3:00				
23101976-005A 03A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:15	10/25/2023 3:00				
23101976-006A 03E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 1:37	10/25/2023 3:00				
23101976-007A 04A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:20	10/25/2023 3:00				
23101976-008A 04E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:24	10/25/2023 3:00				
23101976-009A 05A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:28	10/25/2023 3:00				
23101976-010A 05E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:33	10/25/2023 3:00				
23101976-011A 06A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 0:37	10/25/2023 3:00				
23101976-012A 06E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 1:07	10/25/2023 3:00				
23101976-013A 07A	NELAP	1.0	2.1	μg/L	1	11/02/2023 1:12	10/25/2023 3:00				
23101976-014A 07E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 1:16	10/25/2023 3:00				
23101976-015A 08A	NELAP	1.0	2.0	μg/L	1	11/02/2023 1:20	10/25/2023 3:00				
23101976-016A 08E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 1:25	10/25/2023 3:00				
23101976-017A 09A	NELAP	1.0	6.0	μg/L	1	11/02/2023 2:34	10/25/2023 3:00				
23101976-018A 09E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 1:29	10/25/2023 3:00				
23101976-019A 10A	NELAP	1.0	2.2	μg/L	1	11/02/2023 1:33	10/25/2023 3:00				
23101976-020A 10E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 2:03	10/25/2023 3:00				
23101976-021A 11A	NELAP	1.0	4.6	μg/L	1	11/02/2023 2:08	10/25/2023 3:00				
23101976-022A 11E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 2:12	10/25/2023 3:00				
23101976-023A 12A	NELAP	1.0	8.2	μg/L	1	11/02/2023 2:16	10/25/2023 3:00				
23101976-024A 12E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 2:21	10/25/2023 3:00				
23101976-025A 13A	NELAP	1.0	2.2	μg/L	1	11/02/2023 2:25	10/25/2023 3:00				
23101976-026A 13E	B NELAP	1.0	< 1.0	μg/L	1	11/02/2023 2:29	10/25/2023 3:00				
23101976-027A 14A	NELAP	1.0	2.2	μg/L	5	11/02/2023 17:02	10/25/2023 3:00				
23101976-028A 14E	NELAP	1.0	2.3	μg/L	1	11/02/2023 3:30	10/25/2023 3:00				
23101976-029A 15A	NELAP	1.0	6.0	μg/L	1	11/02/2023 3:00	10/25/2023 3:00				
23101976-030A 15E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 3:04	10/25/2023 3:00				
23101976-031A 16A	NELAP	1.0	6.5	μg/L	1	11/02/2023 3:08	10/25/2023 3:00				
23101976-032A 16E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 3:13	10/25/2023 3:00				
23101976-033A 17	NELAP	1.0	< 1.0	μg/L	5	11/02/2023 16:45	10/25/2023 3:00				
23101976-034A 18A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 15:20	10/25/2023 3:00				
23101976-035A 18E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 15:49	10/25/2023 3:00				
23101976-036A 19A	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 15:53	10/25/2023 3:00				
23101976-037A 19E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 15:57	10/25/2023 3:00				
23101976-038A 20A	NELAP	1.0	3.2	μg/L	1	11/02/2023 16:01	10/25/2023 3:00				
23101976-039A 20E	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 16:05	10/25/2023 3:00				
23101976-040A 21	NELAP	1.0	< 1.0	μg/L	1	11/02/2023 16:09	10/25/2023 3:00				
23101976-041A 22A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:37	10/25/2023 3:00				
23101976-042A 22E	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:41	10/25/2023 3:00				
23101976-043A 23A	A NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:45	10/25/2023 3:00				
23101976-044A 23E	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:49	10/25/2023 3:00				
23101976-045A 24A	A NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:53	10/25/2023 3:00				
23101976-046A 24E		1.0	< 1.0	μg/L	1	11/03/2023 13:17	10/25/2023 3:00				
23101976-047A 25A		1.0	< 1.0	μg/L	1	11/03/2023 13:21	10/25/2023 3:00				
23101976-048A 25E	B NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:25	10/25/2023 3:00				



Laboratory Results

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101976

Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1. Lead	4, 200.8 R5.4, META)						
	NA 00A	NELAD	4.0			4	44/00/0000 40 00	40/05/0000 0 00
23101976-049	9A 26A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:29	10/25/2023 3:00
23101976-050)A 26B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 13:33	10/25/2023 3:00



Receiving Check List

http://www.teklabinc.com/

Work Order: 23101976 Client: Environmental Consultants, LLC Client Project: Wentzville SD Water Sampling 231000104 Boone Trail Report Date: 06-Nov-23 Carrier: Devon Rathbun Received By: HAW Elizabeth a Hurley Completed by: Reviewed by: On: On: 26-Oct-23 27-Oct-23 Elizabeth A. Hurley Ellie Hopkins Extra pages included 0 Pages to follow: Chain of custody Shipping container/cooler in good condition? Yes **✓** No 🗔 Not Present Temp °C NA Type of thermal preservation? **~** Ice _ Blue Ice None Dry Ice Chain of custody present? **~** No L Yes Chain of custody signed when relinquished and received? **~** Yes No L **~** Chain of custody agrees with sample labels? No 🗀 Yes **~** Samples in proper container/bottle? Yes No 🗀 **V** Sample containers intact? Yes No Sufficient sample volume for indicated test? Yes No **~** No \square All samples received within holding time? Yes NA 🗸 Field Lab 🗌 Reported field parameters measured: Yes 🗸 No \square Container/Temp Blank temperature in compliance? When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected. No VOA vials ✓ Water - at least one vial per sample has zero headspace? Yes 🗌 No 🗀 No TOX containers Water - TOX containers have zero headspace? Yes No 🗌 Yes 🗹 No 🗌 Water - pH acceptable upon receipt?

Yes

Any No responses must be detailed below or on the COC.

No 🗀

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

NPDES/CWA TCN interferences checked/treated in the field?

NA 🗸

pg. 1 of 9 Work Order \$ 23/01970

Client: J. S. Held							_		Sam	ples	on). I]	16 Î	J Blue	lce	χN	i Ice		N	IK.	e (C		
Address: 6 Meadow Heigh	hts Profi	Park							Prei	GLA(ėd i	n.	X	.alo	J Blue O F	ield	ľ	or 1	<u> </u>	USE (oml'	<u>C</u>		
City State Zip: Collinsuille, IL 6	2234	16 mm						100	Lab				U											
Contact: Jim Yasitis	Phon	e: 618-	343	- 3	590																			
E-Mail: james. yasitis@jsheld.com	n Fax:	618	-343	-35	97				Con 12				77-	o.1	E ieu	Y 20 1 - 2 - 2		C .	1					
 Are these samples known to be involved in lition Are these samples known to be hazardous? Are there any required reporting limits to be maked in limits in comment section. 图 Yes 	JYes ⊠ N	D			-	•		🏻							29b.			-r	<i></i>	e t				
Project Name / Number	Sa	mple Col	lecto	or's	Nam	ie	•			MA	TRI	X				INDIC	ATE	ANA	LYSI	SRE	QUE	STEL)	
Wentzuille SD Water Sampling 231000104	Brad	Frisch								(eer					mady ####	in group and the						-		
Results Requested Bi	Iling Instru	ctions	# an	d Ty	/pe o	f Co	ntair	iers		Water		A CONTRACTOR OF THE PARTY OF TH	e	(DM)		the second	Market Personal					, and the same		
☑ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)			E S		- S			Š		King		ge	Wasí	~			NATE OF THE PROPERTY OF THE PR		!		Land Comment		and the second	
Lab: Use Only Sample Identification	BatalTima	Samulad	UNPRES		M2SO4	2		NES O	Water	Drinking	Soil	Sluo	200	eac	1000		A Paris de la Caracteria de la Caracteri			The state of the s				
23/0141/00 014	10.25.23	~~~~	X			500	2	5 0		X	-			X		_	 	 	-				-	
ASTURIU IVI OTA	10,32,33	5.00	-	+	-			\dashv	-	$\frac{1}{x}$			***************************************	~			+	-	-					
007 OIB	 		X	-	+	\vdash	-	-		+	-	-		<u> </u>		_	-		-					
003 O 2 A	 		X	-	_	-	-			+	-			X			-	-	+	-				
004 03 B			<u> r </u>	-	-	-		-	-	1x	-	-		X			-	 	 	1-				
103 A	<u> </u>		X	 }		 			-	_	-	-		X			 	-	-	+	 	\	 	
00v 03B			X	_		+-	-			X	-	-	-	入			-	+-	+	+	╁──	 		
001 044			_X	-	_	-		_	_	X	-	ا ــــ		K		_	+	-	-	-	-	+		
008 04B			χ	_		-			-	ļχ	and the same	<u> </u>	<u> </u>	1				-	-		1		<u> </u>	
109 054	1		X			╀		-		X		<u> </u>	<u> </u>	X	-		<u> </u>		-			-		
010 058			X						1	<u> </u> X		<u></u>		X	<u></u>			<u> </u>	<u> </u>			l te / T		
Relinquished By	a de la companya de l	1000			Tim	e	-	مارستان جا جزست			into la series e	~	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	-	eived E	ah			-	120				NAMES OF THE PERSON NAMED OF T
Devon · Rathbun		10.25.	<i>30.</i>	73						do	<u>L</u> c		ساما	ye_			and the second second	AND THE PROPERTY OF THE PROPER	110	1201	25		<u> </u>	
					والموادية والمالية والم			(-	entrato es as	Lingspiel Challen	- Maria Caraca	and the second second second			en estatuenen en en estatuen en	-		***************************************			
	·			·	and the second second	الرواد المساوية		···		-0				eritaine parties	rai Mana Mikita (43 np. Mikita (43 np. 1	ACCOUNTS OF THE PERSONS ASSESSMENT			+		CO-CANDER CONTINUE		**************************************	-garaneero-compositionaminocodinas
The individual cigning this grown and at least	1. 15 5 ti .	<u>L</u>			. , .										4								· .	

pg. 2 of 9 Work Order # <u>33101970</u>

Client: J. S. Held							-		Jam	ples	; on	Ľ] [c	18 I	I Bh	ia:lce	Ę	l N	o Ica				°C:			
Address: 6 Meadow Hei	ghts Prof Po	ark					_ .		⁹ res	GLA(ed i	0.1	21	alb		Field		F	or i	AB	use	OML	Y			
City State Zip: Collinsville, IL	6.2234	.,					_		.ab	Nob	HS.															
Contact: Jim Vasitis	Phone	: 618-	343	359	0		-																			
E-Mail: james. yasitis@jsheld.co	m Fax:	618-	343.	359	7		-		Com 12				Tre	3,1	Ξæ	WY#≥1	***		ζ.	7.	u** 1					
PAre these samples known to be involved in lift Are these samples known to be hazardous? Are there any required reporting limits to be relimits in comment section.	☐ Yes ☑ No		_			•		. 🏻							<u> </u>					<i>a</i> v	4 1					
Project Name / Number	San	ple Col	lecto	r's N	ami	e .				MA"	TRD	{				IND	ICA	TE ,	ANA	Lysi	IS RE	QUE	STE	\overline{D}		
Wentzuille SD Water Sampling 231000704	Brad 1	Frisch						ļ		ofter.	and the second second	and or published the		_	and the second	The grant production of the control	eropetta fotoscore									
Results Requested B ■ Standard □ 1-2 Day (100% Surcharge)	illing Instruc	tions	# and					-		A ANG	***************************************		2	(DM)			de constant de la con									
☐ Other ☐ 3 Day (50% Surcharge)			UNPRES	NaOH	00		1804	10	Water	Drinking Water	Soil	nogo.	. Was	a d		And the second s						and the second s				
Lab Use Only Sample Identification	Date/Time S	ampled		Na	Z Z	Z Z	S S	50	8	à	Й	ā	S .	7												
BIDITIFUL 06A	10.25.23	3:00	X							χ		·		X								ļ			<u> </u>	
012 06B			γ							X				X			Ì	. 1			<u> </u>					
DI3 07A			X							X		THE PERSON NAMED IN		x										-		
014 073			8			\neg				X				γ												
015 084			Y							X				X												
UV 08B			χ							X				x									·			
017 094			λ							ľχ				χ				quarrantes o'g tal							<u> </u>	
DIX 09B	,		X							1/2				X			STATE OF THE PARTY						<u> </u>	<u>.</u>		
819 loA			κ							γ				χ												
DH 10B	1	-	X	1		T.				X			********	X												
Relinquished By			سلسكاد	e / Ti	we	<u></u>		<u>ــــــــــــــــــــــــــــــــــــ</u>	<u>"</u> T		<u> </u>			Rece	eived	By				Ì.		Da	te / 1	ime		
Devon Rathlin .		10.25.	<i>ጔ∂2</i>	3					þ	No		<u>A</u>		<u> </u>	anoxamine to a 12		.Aug-tropic		~~~	10	120	5/2	3_	087	32	
								· · · · · · · · · · · · · · · · · · ·		-	سور سنجب	oranie toe	-		**************************************	·	···········	, and the same of the same	<u> </u>	-						
	·		Charles and the Control of the Contr			····	TOTAL PROPERTY AND ADDRESS OF THE PARTY AND AD							Mariana Real Marie		15th page 15th Control of the State of the S	<u> </u>			ļ						
																				<u> </u>						

pg. 3 of 9 Work Order # 2310197U

Client: J. S. Held						-									I BN								°C			
Address: 6 Meadow Heig	hts Prof,	Park						Ē	reb	31.4.c	ect is	L. Ĺ	14	alo.		Fiel	ď	F	OR I	<u> 48</u>	USE	ONL	Ľ			
City State Zip: Collinsuille, IL 6	2234								alb l	(IO)	85)															
Contact: Jim Vasitis	Phon	e: 618-	343-	359	0	-																				
E-Mail: james. yasitis@jsheld.com	n Fax:	618	-343-	359	7				ìom 12				7:0	1.1	= (e)	mo e			€.	, .	. 6					
 Are these samples known to be involved in little Are these samples known to be hazardous? Are there any required reporting limits to be making limits in comment section. 	JYes ⊠N	D	_			•									ppl				er.	en w	V I					
Project Name / Number	Sa	mple Col	lecto	's N	ame		-			MAT	rix	(INL)IC/	NTE !	ANA	LYSI	SRE	QUE	STE	D,		
Wentzuille SD Water Sampling 231000104	Brad	Frisch	mar of the state o							Water	and the special section of	again and a second	-	(-	Control of the Contro	approximate								
Results Requested Bi	lling Instru	ctions	# and					rs		a Wa	C. C	65	g .	(DM)			to the second									
図 Standard 🗆 1-2 Day (100% Surcharge)	-		3ES]]	Z	E	Š	Las	,jej	Orinking \		Studge	Se As	~			agree webs state of the									
Lab Use Only Sample Identification	Date/Time	Sampled	UNPRES	Oe Z	1280		NaHSO4	Othe	Water	Oric	800		ė.	Lea	The same of the sa	A COLUMN TO A COLU	***************************************				and the second second				•	
23101971V-141 11A	10.25.23		X	1.	_					X			┪	X												
0,2 118			Y	1-1	十					X	1	7		X				.27								·
DX 12A			X		1					χ	1			x	1						Ì					
024 12B			r		7	┪				X	_			γ								-				
1X 13A						_				x				×						·						
13B			V.							1	7	7		ょ												
D) 14A			$ \chi $							γ				χ												
1413			χ			1				λ				χ												
13A 15A			x	1		\top	T			γ			·	Υ			***************************************		-	1	-					
120 ISB	1		X	+		+		-		χ				X		Ì	- Charles Wilder		1							
Relinquished By	<u>'</u>		الا	! Ti	me me		<u> </u>	<u></u>		<u></u>				Rece	ived	By	-	حصصا				Dat	e/T	ime		اعصيطه
Devon Rathlin.		10.25.	302	3					ď	40	<u>_d</u>		1/-) <u>o</u> _						امرأ	125	123		08	32	<u> </u>
																						C. C	-			
																	and the same of th		······································							
The individual cigning this agreement on help																	-									

pg. 4 of 9 Work Order \$ 23101970

Client: J. S. Held						10000								lca						°C			
Address: 6 Meadow Heights	Prof Park				_		resc	ilag	ci ix	IV E	I Lat	J	OF	eid .	ľ	OR 1	A8	USE	ONL	Ľ			
City / State / Zip: Collinsuille, IL 622	234		·				ab f	lok)	â														
Contact: Jim Vasitis	Phone: 6/8-	343-3	3590	············																			
E-Mail: james. yasitis@jsheld.com	Fax: <u>6/8</u> -	348-3	3597		-	100000	001 12)		*****		20.1	F=	iew	EV 170,		ζ.		en e					
PAre these samples known to be involved in litigation Are these samples known to be hazardous? 口Yee Are there any required reporting limits to be met or limits in comment section. 图 Yes □ No) (i										northe	<i>a u</i>						
Project Name / Number Wentzuille SD Water Sampling	Sample Coll	ector'	s Nam				Ñ	ЛАТ	Rix	7			1	NDIC/	ATE.	ANA	Lysi	s re	QUE	STE	D		
231000104 L	Brad Frisch						and the same	alter.	and the second second	gCh. web stordard	(,	- Andrewson of the second							- Andrews	and description on the later hand		
Results Requested Billing E Standard 1-2 Day (100% Surcharge)	- 0		Type of		NAME OF TAXABLE PARTY.	-	-	MA G	COLUMN TO THE PERSON NAMED IN	0,3,5	(ma)	:		Carpenne					i		- Commence of the Commence of	-	
□ Other □ 3 Day (50% Surcharge)	-	UNPRES HNO3	NaOH H2SO4	5	HSO4	ier	Water	Drinking Water	100	Sm Waste	9		W										
Lab Use Only Sample Identification Dat	te/Time Sampled	3 3	Z Z		Z	ő	\$		vā d	\$ E.	100												<u> </u>
23101976-03) 16 A· 10	.25-23 3:00	X	-					\times			ζ												
D332 16 B		γ						X	and the second		λ				.61								
033 17		X ·						χ			X	-										İ	
134 L8A		r						X	1		γ	-									·		
135 183		V						X			λ												
031/194-		χ.			1			r			λ												
DI 19B		$ \chi $						γ			X												
DX 20 A	,	X						x -			X												
014 20.B		K						X) }												
040 21	V	X		ŀ				χ				X											
Relinquished By		<u> </u>	/ Time		_!	<u></u>	Ť	<u> </u>			Re	ceiv	ed By	 ,					Dat	e/Ti	ime		
Devon Rathbon.	10,25.	<i>ڪو</i> 23					Ø	E COL	2	Z	Wo		100 (100 (100 (100 (100 (100 (100 (100				10/	25/	<u>23</u>		<u> 283</u>	<u>2</u>	
		Committee State on the same	and the supplier of the suppli								-			-		dheen er ree	<u> </u>						
			······································				_			·····		الكوار لتعرك المارك المارك		a, a. c.			 						
The individual circums this	, V					********					-						<u> </u>			m=====================================		~====	

pg. <u>5</u> of <u>9</u> Work Order \$. <u>28101970</u>

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005

Address: 6 Meadow Heights Prof Park City State Zip: Collinsville, IL 6,2234							_)res	GLA:	ed i	ια.		_aio	E	Fiel	ď	F	081	AB.	<u>USE</u>	ONL	<u>Y</u>			
City State Zip: Collinsville, IL &	2234						_		.ab	Noi	96°															
Contact: Jim Yasitis	Pho:	ne: <u>6/8</u> -	343	-35	90		_																			
E-Mail: <u>ja<i>mes. yasitis</i>@jsheld.co</u>	m Fax:	618	343	-35,	97		_		Con 12				7 ₂₁ ,	3. I	Εæ	wae.			€.	7						
Are these samples known to be involved in liti Are these samples known to be hazardous? I Are there any required reporting limits to be m limits in comment section. 图 Yes □ No	☐ Yes	lo quested ana	lysis?	If ye	s, plea	Ise p		. 🔯							226	7.										
Project Name / Number Westzulle SD Water Sampling	Si	ample Col	lecto	r's l	lame	•				MA'	ri.	X				INC	<u> DICA</u>	TE	ANA	Lysi	S RE	QUE	STE	<u> </u>		
231000104	Brad	Frisch								fter	and the same of th	Chicago				and the second s	a)Accopication of a	0					-	Sales and the sa		
Results Requested Bi	lling Instr	uctions			e of (Orinking Water		Sludge	ste	(DM)		12/Confessor Days	-							(All markets capturing to the state of the s	-	
□ Other □ □ 3 Day (50% Surcharge)			NE L	z z	ő	1 2	Z S	12	Water	nkin	-	dge	Wa	الم	Control of the last of the las	A The Control of the	TO COMPANY								.	10.10
Lab Use Only Sample Identification	Date/Time	Sampled	N	Na Na	M2SO4	3 2	Z TE	90	W	ā	S	Sku	S.	Lea	OLC PROPERTY.			and the same of th						St. Salatanas de Laca		
13/01976-041 22A	10.25.2		X	ŀ						X		·		X												
042 22B			χ				ALC PROPERTY OF THE PERTY OF TH			X	- Constitution			X						utilization priviled						
043 R3A			X							X				X												
044 23-3			x							X				Y) and the second											
D45 24A			V							X				×			-									
046 243			7		\sqcap	1				X				λ												
D47 25 /4			x			Ť				Y				χ				V					·			
M 25 B			Y	7	\sqcap	1	<u> </u>			1/2				χ												
049 26A	 		X	\dashv		+	\dashv	\top		X			•	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\												
010 26B	1-4	-	X	-	╁┼	╁	-	┪	-	$\frac{x}{x}$				X					 		 					
Relinquished By	1	<u> </u>	11-1	 :e / T	الل			<u> </u>	1	1_				<u> </u>	<u>ll</u> eived	Bv			<u></u>	 	<u> </u>	l	l <u> </u>	ime		<u></u>
Devon Rathbun		10.25.			11116	en tara		OR OTHER DESIGNATION OF THE PERSON OF THE PE	-6	Na		<u> </u>		1)0		wy.		a long deciments		lini	25/	ARRIVA THE PARTY		083	22	
1001 1001 2507)	the second se	1 10 AJ.	J. J. J.	ل.		o-cycreco	enthanty R		-	HT	<u>~</u>	<u> </u>		~~	A LICENSTRANCE	- Andrews (Section)		V	ALCONOMINATORS	191	<u>v</u>	ب لاي		نكك	<u> </u>	
							OLIVOUR BLOW			-		ero-mine Time	estultor-	***************************************					O. Stevenson Programmer		,	Friedrich-ren				
			La Print, and party and				-		_			*************************************		Tagger to see the property of	American Services	TAX V-FINANCE				<u> </u>						
The individual claning this agreement - L. L.	- IF 5 !! .	<u></u>							<u>l_</u>				-				a			<u> </u>						

J.S. Held

Client:

APPENDIX C CREDENTIALS

STATE OF MISSOURI DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Bradley M. Frisch

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date:

3/1/2022

Expiration Date:

3/1/2024

License Number:

160229-300004900



Paula F. Nickelson

Acting Director

Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

PUBLIC HEALTH & SOCIAL JUSTICE

SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

Brad Frisch

2668 Kettering Court, Saint Charles, MO 63303

contact hours of training and successfully passed an examination ∞ has attended

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 - 3/7/2022 - 117395

Christopher C. Kinc

Director, Center for Environmental Education and Training

Examination Date: 3/7/2022

CEUs: 0.8

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104 (314) 977-8256 slu.edu/x39753.xml This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

State of Missouri Department of Natural Resources

Certificate of Approval for Chemical Laboratory Service

This is to certify that

Teklab, Incorporated

is hereby approved to perform the analysis of drinking water as specified on the Certified Parameter List, which must accompany this certificate to be valid.

Certification Number	930	Godflood
Date Issued	December 13, 2021	Laboratory Centification Authority, Public Drinking Water Branch Missouri Department of Natural Resources
Expiration Date	January 31, 2025	Rola Virol
		Laboratory Certification Officer, Environmental Services Program

MISSOURI DEPARTMENT OF NATURAL RESOURCES

DRINKING WATER LABORATORY

CERTIFIED PARAMETER LIST

This is to certify that

Teklab, Incorporated

located at

5445 Horseshoe Lake Road, Collinsville, IL 62234

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

EPA 335.4 Total Cyanide

EPA 353.2Nitrate, Nitrite, Total Nitrate and Nitrite

EPA 245.1 Mercury

EPA 200.7

Barium, Beryllium, Cadmium, Chromium, Copper, Nickel

EPA 200.8

Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Copper, Lead, Nickel, Selenium, Thallium

SM4500F-C Fluoride

SM4500NO2-B Nitrite

Teklab, Incorporated

Expiration Date: January 31, 2025

Missouri Certificate No.: 930 Original Certifying State: Illinois

STATE OF ILLINOIS

ENVIRONMENTAL PROTECTION AGENCY NELAP - RECOGNIZED

ENVIRONMENTAL LABORATORY ACCREDITATION

is hereby granted to

Teklab, Incorporated 5445 Horseshoe Lake Rd. Collinsville, IL 62234 **NELAP ACCREDITED**

Accreditation Number #100226



According to the Illinois Administrative Code, Title 35, Subtitle A, Chapter II, Part 186, ACCREDITATION OF LABORATORIES FOR DRINKING WATER, WASTEWATER AND HAZARDOUS WASTES ANALYSIS, the State of Illinois formally recognizes that this laboratory is technically competent to perform the environmental analyses listed on the scope of accreditation detailed below.

The laboratory agrees to perform all analyses listed on this scope of accreditation according to the Part 186 requirements and acknowledges that continued accreditation is dependent on successful ongoing compliance with the applicable requirements of Part 186. Please contact the Illinois EPA Environmental Laboratory Accreditation Program (IL ELAP) to verify the laboratory's scope of accreditation and accreditation status. Accreditation by the State of Illinois is not an endorsement or a guarantee of validity of the data generated by the laboratory.

Primary Accrediting Authority: Illinois

Millie Rose Supervisor

Environmental Laboratory Accreditation Program

Certificate No: 1002262023-17

Expiration Date: 1/31/2024 Issued On: 4/11/2023

MillicRose

State of Illinois

Environmental Protection Agency

Awards the Certificate of Approval to:

Teklab, Incorporated 5445 Horseshoe Lake Rd. Collinsville, IL 62234

The Illinois Environmental Laboratory Accreditation Program encourages all clients and data users to verify the most current scope of accreditation for Teklab, Incorporated.

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Method EPA 120.1	п
Conductivity	IL
Method EPA 1631E	
Mercury	IL
Method EPA 1664A Rev: 1	
Oil & Grease	IL
Method EPA 180.1 Rev: 2	
Turbidity	IL
Method EPA 200.7 Rev: 4.4	
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Magnesium	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL :
Sodium	IL II
Thallium	IL II
Tin Titanium	IL IL
Vanadium	IL IL
Zinc	IL
	IL
Method EPA 200.8 Rev: 5.4	
Aluminum	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Cadmium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Lead	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Selenium	IL
Silver	IL
Thallium	IL
Vanadium	IL
Zinc	IL
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 335.4 Rev: 1	
Cyanide	IL
Method EPA 350.1 Rev: 2	
Ammonia as N	IL
	12
Method EPA 351.2 Rev: 2	
Total Kjeldahl Nitrogen (TKN)	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Nitrite as N	IL
Method EPA 365.4	
Phosphorus	IL
Method EPA 375.2 Rev: 2	
Sulfate	IL
Method EPA 410.4 Rev: 2	
Chemical oxygen demand	IL
	12
Method EPA 420.1	п
Total phenolics	IL
Method EPA 420.4 Rev: 1	
Total phenolics	IL
Method EPA 608.3 GC-ECD	
4,4'-DDD	IL
4,4'-DDE	IL
4,4'-DDT	IL
Aldrin	IL
alpha-BHC (alpha-Hexachlorocyclohexane)	IL
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Araclar-1242 (PCB-1242)	II

IL

Aroclor-1242 (PCB-1242)

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Non Potable Water) Aroclor-1248 (PCB-1248) IL Aroclor-1254 (PCB-1254) IL Aroclor-1260 (PCB-1260) IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL IL Endosulfan I Endosulfan II IL Endosulfan sulfate IL Endrin IL Endrin aldehyde IL gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL Heptachlor IL Heptachlor epoxide IL Methoxychlor IL IL Toxaphene (Chlorinated camphene) Method EPA 615 2,4,5-T IL 2,4-D IL Dicamba IL Silvex (2,4,5-TP) IL Method EPA 624.1 1,1,1-Trichloroethane IL 1,1,2,2-Tetrachloroethane IL 1,1,2-Trichloroethane IL 1,1-Dichloroethane IL 1,1-Dichloroethylene IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,2-Dichloroethane (Ethylene dichloride) IL 1,2-Dichloropropane IL 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL 2-Chloroethyl vinyl ether IL Acetonitrile IL Acrolein (Propenal) IL Acrylonitrile IL Benzene IL Bromodichloromethane IL IL Bromoform IL Carbon tetrachloride Chlorobenzene IL Chlorodibromomethane IL Chloroethane (Ethyl chloride) IL Chloroform IL cis-1,3-Dichloropropene IL Ethylbenzene IL Methyl bromide (Bromomethane) IL Methyl chloride (Chloromethane) IL Methyl tert-butyl ether (MTBE) IL Methylene chloride (Dichloromethane) IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Non Potable Water) Tetrachloroethylene (Perchloroethylene) IL Toluene IL trans-1,2-Dichloroethylene IL trans-1,3-Dichloropropylene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL IL Vinyl chloride IL Xylene (total) Method EPA 625.1 1,2,4-Trichlorobenzene IL 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,6-Trichlorophenol IL IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL 2-Nitrophenol IL 3,3'-Dichlorobenzidine IL IL 4-Bromophenyl phenyl ether IL 4-Chloro-3-methylphenol 4-Chlorophenyl phenylether IL 4-Nitrophenol IL Acenaphthene IL Acenaphthylene IL Anthracene IL Benzidine IL Benzo(a)anthracene IL Benzo(a)pyrene IL Benzo(b)fluoranthene IL IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chrysene IL IL Dibenz(a,h) anthracene Diethyl phthalate IL Dimethyl phthalate IL IL Di-n-butyl phthalate Di-n-octyl phthalate IL Fluoranthene ILFluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL IL Hexachlorocyclopentadiene Hexachloroethane IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Indeno(1,2,3-cd) pyrene	IL
Isophorone	IL
Naphthalene	IL
Nitrobenzene	IL
n-Nitrosodimethylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
Pentachlorophenol Phenanthrene	IL IL
Phenol	IL IL
Pyrene	IL
Pyridine	IL
Method OIA 1677-09	
Available Cyanide	IL
Method SM 2120 B-2011	
Color	IL
Method SM 2130 B-2011	1 <u>L</u>
Turbidity	IL
·	IL.
Method SM 2310 B-2011	IL
Acidity, as CaCO3	IL
Method SM 2320 B-2011	
Alkalinity as CaCO3	IL
Method SM 2340 B-1997	
Hardness	IL
Method SM 2510 B-2011	
Conductivity	IL
Method SM 2540 B-2011	
Residue-total	IL
Method SM 2540 C-2011	
Residue-filterable (TDS)	IL
Method SM 2540 D-2011	
Residue-nonfilterable (TSS)	IL
Method SM 2540 E-2011	
Residue-volatile	IL
Method SM 2540 F-2011	
Residue-settleable	IL
Method SM 3500-Cr B-2011	
Chromium VI	IL
Method SM 4500-CI G-2011	
Total residual chlorine	IL
Method SM 4500-CI C-1997	
Chloride	IL
Method SM 4500-Cl C-2011	
Chloride	IL
Method SM 4500-Cl E-2000	· -
Chloride	IL
	12
Method SM 4500-CI E-2011	

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water) Chloride	IL
Method SM 4500-F C-2011 Fluoride	IL
Method SM 4500-H+ B-2011 pH	IL
Method SM 4500-NH3 G-2011 Ammonia	IL
Method SM 4500-NO2 B-2011 Nitrite	IL
Method SM 4500-NO3 F-2000 Nitrate plus Nitrite as N	IL
Method SM 4500-O G-2001 Oxygen, dissolved	IL
Method SM 4500-P E-2011 Orthophosphate as P	IL
Method SM 4500-S2 D-2011 Sulfide	IL
Method SM 4500-SO3 B-2011 Sulfite-SO3	IL
Method SM 5210 B-2011 Biochemical oxygen demand Carbonaceous BOD, CBOD	IL IL
Method SM 5220 D-2011 Chemical oxygen demand	IL
Method SM 5310 C-2011 Total organic carbon	IL
Method SM 5540 C-2011 Surfactants - MBAS	IL

Field of Testing /Matrix: CWA (Solid & Hazardous Material)	
Method EPA 160.4	
Residue-volatile	IL
	·-
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 351.2 Rev: 2	
Total Kjeldahl Nitrogen (TKN)	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Nitrite as N	IL
Method EPA 365.4	
Phosphorus	IL
Method EPA 420.1	
Total phenolics	IL
Method EPA 608.3 GC-ECD	
4,4'-DDD	IL
4,4'-DDE	IL IL
4,4'-DDT	IL
Aldrin	IL
alpha-BHC (alpha-Hexachlorocyclohexane)	IL
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Aroclor-1242 (PCB-1242)	IL
Aroclor-1248 (PCB-1248)	IL
Aroclor-1254 (PCB-1254)	IL
Aroclor-1260 (PCB-1260)	IL
beta-BHC (beta-Hexachlorocyclohexane)	IL
Chlordane (tech.)(N.O.S.)	IL
delta-BHC	IL
Dieldrin	IL
Endosulfan I	IL
Endosulfan II	IL
Endosulfan sulfate	IL
Endrin	IL
Endrin aldehyde	IL
gamma-BHC (Lindane, gamma-Hexachlorocyclohexane)	IL
Heptachlor	IL
Heptachlor epoxide	IL
Methoxychlor	IL
Toxaphene (Chlorinated camphene)	IL
Method EPA 624.1	
1,1,1-Trichloroethane	IL
1,1,2,2-Tetrachloroethane	IL
1,1,2-Trichloroethane	IL
1,1-Dichloroethane	IL
1,1-Dichloroethylene	IL
1,2-Dichlorobenzene (o-Dichlorobenzene)	IL
1,2-Dichloroethane (Ethylene dichloride)	IL
1,2-Dichloropropane	IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Solid & Hazardous Material) 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL 2-Chloroethyl vinyl ether IL Acetonitrile IL Acrolein (Propenal) IL IL Acrylonitrile Benzene IL Bromodichloromethane IL Bromoform IL Carbon tetrachloride IL Chlorobenzene IL Chlorodibromomethane IL Chloroethane (Ethyl chloride) IL Chloroform IL IL cis-1,3-Dichloropropene IL Ethylbenzene Methyl bromide (Bromomethane) IL Methyl chloride (Chloromethane) IL Methyl tert-butyl ether (MTBE) IL Methylene chloride (Dichloromethane) IL Tetrachloroethylene (Perchloroethylene) IL Toluene IL IL trans-1,2-Dichloroethylene trans-1,3-Dichloropropylene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL Vinyl chloride IL Xylene (total) IL Method EPA 625.1 1,2,4-Trichlorobenzene IL 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,6-Trichlorophenol IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol IL 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL 2-Nitrophenol IL IL 3,3'-Dichlorobenzidine 4-Bromophenyl phenyl ether IL 4-Chloro-3-methylphenol IL 4-Nitrophenol IL Acenaphthene IL Acenaphthylene IL Anthracene IL Benzidine IL Benzo(a)anthracene IL IL Benzo(a)pyrene Benzo(b)fluoranthene IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Solid & Hazardous Material)	
Benzo(g,h,i)perylene	IL
Benzo(k)fluoranthene	IL
bis(2-Chloroethoxy)methane	IL
bis(2-Chloroethyl) ether	IL
bis(2-Ethylhexyl) phthalate (DEHP)	IL
Butyl benzyl phthalate	IL
Carbazole	IL
Chrysene	IL
Dibenz(a,h) anthracene	IL
Diethyl phthalate	IL
Dimethyl phthalate	IL
Di-n-butyl phthalate	IL
Di-n-octyl phthalate	IL
Fluoranthene	IL
Fluorene	IL
Hexachlorobenzene	IL
Hexachlorobutadiene	IL
Hexachlorocyclopentadiene	IL
Hexachloroethane	IL
Indeno(1,2,3-cd) pyrene	IL
Isophorone	IL
Naphthalene	IL
Nitrobenzene	IL
n-Nitrosodimethylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
Pentachlorophenol	IL
Phenanthrene Phenol	IL
	IL
Pyrene	IL
Pyridine	IL
Method SM 2340 B-1997	
Hardness	IL
Method SM 2540 C-1997	
Residue-filterable (TDS)	IL
Method SM 2540 F-1997	
Residue-settleable	IL
Method SM 4500-CI C-1997	
Chloride	IL
Method SM 4500-Cl C-2011	16
	11
Chloride	IL
Method SM 4500-CI E-2000	
Chloride	IL
Method SM 4500-NO2 B-2011	
Nitrite	IL
Method SM 4500-NO3 F-2000	
Nitrate plus Nitrite as N	IL
Method SM 4500-P E-1999	
Orthophosphate as P	IL
Οι πορποσμιαί ο ασ τ	IL.

Certificate No.: 1002262023-17 Primary AB

Field of Testing /Matrix: CWA (Solid & Hazardous Material)

Method SM 4500-SO3 B-2000

Sulfite-SO3

Certificate No.: 1002262023-17 Primary AB

Certificate No.: 1002262023-17	
Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 1010A	
Ignitability	IL
Method EPA 1020B	
Ignitability	IL
Method EPA 1311 Rev: 0	
Toxicity Characteristic Leaching Procedure (TCLP)	IL
Method EPA 1312 Rev: 0	1.2
Synthetic Precipitation Leaching Procedure (SPLP)	IL
	IL
Method EPA 6010B Rev: 2 Aluminum	IL
Antimony	IL IL
Arsenic	IL
Barium	IL
Beryllium	iL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Lithium	IL
Magnesium	IL "
Manganese	IL IL
Molybdenum Nickel	IL IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL
Sodium	IL
Strontium	IL
Thallium	IL
Tin	IL
Titanium	IL
Vanadium	IL
Zinc	IL
Method EPA 6020A Rev: 1	
Aluminum	IL
Antimony	IL
Arsenic	IL "
Barium	IL II
Beryllium Boron	IL IL
Boron Cadmium	IL IL
Cadmium	IL IL
Chromium	IL IL
Cobalt	IL
Copper	IL
	· -

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: RCRA (Non Potable Water) Iron IL Lead IL Magnesium IL Manganese IL Molybdenum IL Nickel IL Potassium IL Selenium IL Silver IL Sodium IL **Thallium** IL Vanadium IL IL Zinc Method EPA 7196A Rev: 1 Chromium VI IL Method EPA 7470A Rev: 1 Mercury IL Method EPA 8015B Rev: 2 IL Diesel range organics (DRO) Ethanol IL Ethylene glycol IL Isobutyl alcohol (2-Methyl-1-propanol) IL Isopropyl alcohol (2-Propanol, Isopropanol) IL IL Methanol n-Butyl alcohol (1-Butanol, n-Butanol) IL n-Propanol (1-Propanol) IL IL tert-Butyl alcohol Method EPA 8081B 4,4'-DDD IL 4,4'-DDE IL 4,4'-DDT IL Alachlor IL Aldrin IL IL alpha-BHC (alpha-Hexachlorocyclohexane) alpha-Chlordane, cis-Chlordane IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL Endosulfan I IL Endosulfan II IL Endosulfan sulfate IL **Endrin** IL Endrin aldehyde IL Endrin ketone IL gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL gamma-Chlordane IL Heptachlor IL Heptachlor epoxide IL Methoxychlor IL Toxaphene (Chlorinated camphene) IL

Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 8082 Rev: 0	
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Aroclor-1242 (PCB-1242)	IL
Aroclor-1248 (PCB-1248)	IL
Aroclor-1254 (PCB-1254)	IL
Aroclor-1260 (PCB-1260)	IL
Method EPA 8151A	
2,4,5-T	IL
2,4-D	IL
2,4-DB	IL
3,5-Dichlorobenzoic acid	IL
4-Nitrophenol	IL
Acifluorfen	IL
Bentazon	IL
Chloramben	IL
Dalapon	IL
DCPA di acid degradate	IL
Dicamba	IL
Dichloroprop (Dichlorprop)	IL
Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP)	IL
MCPA	IL IL
MCPP	IL "
Pentachlorophenol	IL "
Picloram	IL
Silvex (2,4,5-TP)	IL
Method EPA 8260B	
1,1,1,2-Tetrachloroethane	IL
1,1,1-Trichloroethane	IL
1,1,2,2-Tetrachloroethane	IL
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	IL
1,1,2-Trichloroethane	IL
1,1-Dichloroethane	IL
1,1-Dichloroethylene	IL
1,1-Dichloropropene	IL
1,2,3-Trichlorobenzene	IL
1,2,3-Trichloropropane	IL
1,2,4-Trichlorobenzene	IL
1,2,4-Trimethylbenzene	IL
1,2-Dibromo-3-chloropropane (DBCP)	IL
1,2-Dibromoethane (EDB, Ethylene dibromide)	IL
1,2-Dichlorobenzene (o-Dichlorobenzene)	IL
1,2-Dichloroethane (Ethylene dichloride)	IL
1,2-Dichloropropane	IL
1,3,5-Trimethylbenzene	IL
1,3-Dichlorobenzene	IL
1,3-Dichloropropane	IL
1,4-Dichlorobenzene	IL
1-Chlorobutane	IL
2,2-Dichloropropane	IL

ld of Testing /Matrix: RCRA (Non Potable Water)	
2-Butanone (Methyl ethyl ketone, MEK)	IL
2-Chloroethyl vinyl ether	IL
2-Chlorotoluene	iL
2-Hexanone	iL
2-Nitropropane	IL
4-Chlorotoluene	iL
4-Isopropyltoluene (p-Cymene,p-Isopropyltoluene)	IL
4-Methyl-2-pentanone (MIBK)	IL
Acetone	IL
Acetonitrile	IL
Acrolein (Propenal)	IL
Acrylonitrile	IL
Allyl chloride (3-Chloropropene)	IL
Benzene	IL
Bromobenzene	IL
Bromochloromethane	IL
Bromodichloromethane	iL
Bromoform	iL
Carbon disulfide	iL
Carbon tetrachloride	iL
Chlorobenzene	IL
Chlorodibromomethane	IL
Chloroethane (Ethyl chloride)	IL
Chloroform	IL
Chloroprene (2-Chloro-1,3-butadiene)	IL
cis-1,2-Dichloroethylene	IL
cis-1,3-Dichloropropene	IL
cis-1,4-Dichloro-2-butene	IL
Dibromomethane (Methylene bromide)	IL
Dichlorodifluoromethane (Freon-12)	IL
Diethyl ether	IL
Di-isopropylether (DIPE) (Isopropyl Ether)	IL
Ethyl acetate	IL
Ethyl methacrylate	IL
Ethylbenzene	IL
Hexachlorobutadiene	IL
Hexachloroethane	IL
Iodomethane (Methyl iodide)	IL
Isopropylbenzene	IL
m+p-xylene	IL
Methacrylonitrile	IL
Methyl acrylate	IL
Methyl bromide (Bromomethane)	IL
Methyl chloride (Chloromethane)	IL
Methyl methacrylate	IL
Methyl tert-butyl ether (MTBE)	IL
Methylene chloride (Dichloromethane)	IL.
m-Xylene	iL
Naphthalene	iL
n-Butylbenzene	IL
Nitrobenzene	IL
n-Propylbenzene	iL

Certificate No.: 1002262023-17 Primary AB

Certificate 140 1002202011	
Field of Testing /Matrix: RCRA (Non Potable Water)	
o-Xylene	IL
Pentachloroethane	IL
Propionitrile (Ethyl cyanide)	IL
p-Xylene	IL
sec-Butylbenzene	IL
Styrene	IL
tert-Butyl alcohol	IL
tert-Butylbenzene	IL
Tetrachloroethylene (Perchloroethylene)	IL
Tetrahydrofuran (THF)	IL
Toluene	IL
trans-1,2-Dichloroethylene	IL
trans-1,3-Dichloropropylene	IL
	IL
Trichloroethene (Trichloroethylene)	IL
Trichlorofluoromethane (Fluorotrichloromethane, Freon 11)	IL
	IL
·	IL
·	IL
Method EPA 8270C Rev: 3	
	IL
	IL
·	IL
	IL
	IL
	IL
·	IL
·	IL IL
	IL
·	IL IL
	IL
	IL IL
·	IL IL
	IL IL
· · · · · · · · · · · · · · · · · · ·	IL IL
•	IL IL
·	IL IL
·	IL IL
	IL IL
	IL
'	IL
•	IL
	IL
,	IL
	IL
	IL
·	IL
	IL
, ·	IL
4-Chloroaniline	IL

Primary AB Certificate No.: 1002262023-17 RCRA (Non Potable Water) Field of Testing /Matrix: 4-Chlorophenyl phenylether IL 4-Dimethyl aminoazobenzene IL 4-Methylphenol (p-Cresol) IL 4-Nitroaniline IL 4-Nitrophenol IL 5-Nitro-o-toluidine IL IL 7,12-Dimethylbenz(a) anthracene IL Acenaphthene Acenaphthylene IL IL Acetophenone Aniline IL Anthracene IL Benzidine IL Benzo(a)anthracene IL IL Benzo(a)pyrene Benzo(b)fluoranthene IL IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene Benzoic acid IL Benzyl alcohol IL bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chlorobenzilate IL Chrysene IL IL Diallate Dibenz(a,h) anthracene IL Dibenzofuran IL Diethyl phthalate IL IL Dimethoate IL Dimethyl phthalate Di-n-butyl phthalate IL Di-n-octyl phthalate IL Diphenylamine IL Ethyl methanesulfonate IL **Famphur** IL Fluoranthene IL Fluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL Hexachlorocyclopentadiene IL Hexachloroethane IL Hexachloropropene IL Indeno(1,2,3-cd) pyrene IL Isodrin IL Isophorone IL Isosafrole IL Methyl methanesulfonate IL Naphthalene IL

Nitrobenzene

IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Non Potable Water)	
n-Nitrosodiethylamine	IL
n-Nitrosodimethylamine	IL
n-Nitroso-di-n-butylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
n-Nitrosomethylethylamine	IL
n-Nitrosopiperidine	IL
n-Nitrosopyrrolidine	IL
o,o,o-Triethyl phosphorothioate	IL
Parathion	IL
Pentachlorobenzene	IL
Pentachloronitrobenzene	IL
Pentachlorophenol	IL
Phenanthrene	IL
Phenol	IL
Pronamide (Kerb)	IL
Pyrene	IL
Pyridine	IL
Safrole	IL
Method EPA 8270C Mod LVI	
Acetochlor	IL
Alachlor	IL
Atrazine	IL
Butylate	IL
Cyanazine	IL
EPTC (Eptam, s-ethyl-dipropyl thio carbamate)	IL
Metolachlor	IL
Metribuzin	IL
Pendimethalin (Penoxalin)	IL
Simazine	IL ::
Trifluralin (Treflan)	IL
Method EPA 9012A Rev: 1	
Cyanide	IL
Method EPA 9014 Rev: 0	
Cyanide	IL
Method EPA 9020B Rev: 2	
Total organic halides (TOX)	IL
Method EPA 9023 Rev: 0	· -
Extractable organics halides (EOX)	IL
	IL
Method EPA 9036 Rev: 0	
Sulfate	IL
Method EPA 9040B Rev: 2	
pH	IL
Method EPA 9050A Rev: 1	
Conductivity	IL
Method EPA 9060A	
Total organic carbon	IL
Method EPA 9065 Rev: 0	. <u>-</u>
	IL
Total phenolics	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 9066 Rev: 0 Total phenolics	IL
Method EPA 9095A Paint Filter Test	IL
Method EPA 9214 Rev: 0 Fluoride	IL
Method EPA 9251 Rev: 0 Chloride	IL

Certificate No.: 1002262023-17

Certificate No.: 1002262023-17	
Field of Testing /Matrix: RCRA (Solid & Hazardous Material)	
Method EPA 1010A	
Ignitability	IL
Method EPA 1020B	
Ignitability	IL
Method EPA 1311 Rev: 0	
Toxicity Characteristic Leaching Procedure (TCLP)	IL
Method EPA 1312 Rev: 0	12
Synthetic Precipitation Leaching Procedure (SPLP)	IL
	IL
Method EPA 6010B Rev: 2 Aluminum	IL
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Lithium	IL
Magnesium	IL "
Manganese	IL IL
Molybdenum Nickel	IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL
Sodium	IL
Strontium	IL
Thallium	IL
Tin	IL
Titanium	IL
Vanadium	IL
Zinc	IL
Method EPA 6020A Rev: 1	
Aluminum	IL
Antimony	IL
Arsenic	IL "
Barium Barilium	IL IL
Beryllium Boron	IL IL
Cadmium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Lead IL Magnesium IL IL Manganese Molybdenum IL Nickel IL IL Potassium Selenium IL Silver IL Sodium IL **Thallium** IL Vanadium IL Zinc IL Method EPA 7196A Rev: 1 IL Chromium VI Method EPA 7471B Mercury IL Method EPA 8015B Rev: 2 Diesel range organics (DRO) IL IL Ethanol Ethylene glycol IL Isobutyl alcohol (2-Methyl-1-propanol) IL Isopropyl alcohol (2-Propanol, Isopropanol) IL Methanol IL IL n-Butyl alcohol (1-Butanol, n-Butanol) n-Propanol (1-Propanol) IL tert-Butyl alcohol IL Method EPA 8081B 4,4'-DDD IL 4,4'-DDE IL 4,4'-DDT IL Alachlor IL Aldrin IL alpha-BHC (alpha-Hexachlorocyclohexane) IL alpha-Chlordane, cis-Chlordane IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL Endosulfan I IL Endosulfan II IL Endosulfan sulfate IL Endrin IL IL Endrin aldehyde IL Endrin ketone gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL gamma-Chlordane IL Heptachlor IL Heptachlor epoxide IL IL Methoxychlor Toxaphene (Chlorinated camphene) IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Aroclor-1016 (PCB-1016) IL Aroclor-1221 (PCB-1221) IL Aroclor-1232 (PCB-1232) IL Aroclor-1242 (PCB-1242) IL Aroclor-1248 (PCB-1248) IL Aroclor-1254 (PCB-1254) IL Aroclor-1260 (PCB-1260) IL Method EPA 8151A 2.4.5-T IL 2,4-D IL 2,4-DB IL 3,5-Dichlorobenzoic acid IL IL 4-Nitrophenol IL Acifluorfen IL Bentazon Chloramben IL Dalapon IL DCPA di acid degradate IL Dicamba IL Dichloroprop (Dichlorprop) IL Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP) IL **MCPA** IL **MCPP** IL IL Pentachlorophenol Picloram IL Silvex (2,4,5-TP) IL Method EPA 8260B 1,1,1,2-Tetrachloroethane IL IL 1,1,1-Trichloroethane IL 1,1,2,2-Tetrachloroethane 1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113) IL 1,1,2-Trichloroethane IL 1,1-Dichloroethane IL 1,1-Dichloroethylene IL 1,1-Dichloropropene IL IL 1,2,3-Trichlorobenzene 1,2,3-Trichloropropane IL 1,2,4-Trichlorobenzene IL IL 1,2,4-Trimethylbenzene 1,2-Dibromo-3-chloropropane (DBCP) IL 1,2-Dibromoethane (EDB, Ethylene dibromide) IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,2-Dichloroethane (Ethylene dichloride) IL 1,2-Dichloropropane IL 1,3,5-Trimethylbenzene IL IL 1,3-Dichlorobenzene 1,3-Dichloropropane IL 1,4-Dichlorobenzene IL 1-Chlorobutane IL 2,2-Dichloropropane IL 2-Butanone (Methyl ethyl ketone, MEK) IL

Certificate No.: 1002262023-17 Primary AB

ld of Testing /Matrix: RCRA (Solid & Hazardous Material)	
2-Chloroethyl vinyl ether	IL
2-Chlorotoluene	IL
2-Hexanone	iL
2-Nitropropane	IL
4-Chlorotoluene	IL
4-Isopropyltoluene (p-Cymene,p-Isopropyltoluene)	IL
4-Methyl-2-pentanone (MIBK)	IL
Acetone	IL
Acetonitrile	IL
Acrolein (Propenal)	IL
Allyl chloride (3-Chloropropene)	IL
Benzene	IL
Bromobenzene	IL
Bromochloromethane	L
Bromodichloromethane	L "
Bromoform	IL
Carbon disulfide	IL
Carbon tetrachloride	IL
Chlorobenzene	IL
Chlorodibromomethane	IL
Chloroethane (Ethyl chloride)	IL
Chloroform	IL
Chloroprene (2-Chloro-1,3-butadiene)	IL
cis-1,2-Dichloroethylene	IL
cis-1,3-Dichloropropene	IL
cis-1,4-Dichloro-2-butene	IL
Dibromomethane (Methylene bromide)	IL
Dichlorodifluoromethane (Freon-12)	IL
Diethyl ether	IL
Di-isopropylether (DIPE) (Isopropyl Ether)	IL
Ethyl acetate	IL
Ethyl methacrylate	IL
Ethylbenzene	IL
Hexachlorobutadiene	IL
Hexachloroethane	IL
lodomethane (Methyl iodide)	IL
Isopropylbenzene	IL
m+p-xylene	IL
Methacrylonitrile	IL
Methyl acrylate	IL
Methyl bromide (Bromomethane)	IL
Methyl chloride (Chloromethane)	IL
Methyl methacrylate	IL
Methyl tert-butyl ether (MTBE)	IL
Methylene chloride (Dichloromethane)	IL
m-Xylene	IL
Naphthalene	IL
n-Butylbenzene	IL
Nitrobenzene	IL
n-Propylbenzene	IL
o-Xylene	IL
Pentachloroethane	IL IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Propionitrile (Ethyl cyanide) IL p-Xylene IL sec-Butylbenzene IL Styrene IL tert-Butyl alcohol IL tert-Butylbenzene IL IL Tetrachloroethylene (Perchloroethylene) IL Tetrahydrofuran (THF) Toluene IL trans-1,2-Dichloroethylene IL trans-1,3-Dichloropropylene IL trans-1,4-Dichloro-2-butene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL Vinyl acetate IL Vinyl chloride IL IL Xylene (total) Method EPA 8270C Rev: 3 1,2,4-Trichlorobenzene IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL IL 1,4-Dioxane (1,4- Diethyleneoxide) 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,5-Trichlorophenol IL 2,4,6-Trichlorophenol IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol IL 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL IL 2-Methylaniline (o-Toluidine) 2-Methylnaphthalene IL 2-Methylphenol (o-Cresol) IL 2-Nitroaniline IL 2-Nitrophenol IL 3,3'-Dichlorobenzidine IL 3-Methylphenol (m-Cresol) IL IL 3-Nitroaniline IL 4-Bromophenyl phenyl ether 4-Chloro-3-methylphenol IL 4-Chloroaniline IL 4-Chlorophenyl phenylether IL 4-Methylphenol (p-Cresol) IL4-Nitroaniline IL 4-Nitrophenol IL Acenaphthene IL

Acenaphthylene

Aniline

IL

IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: RCRA (Solid & Hazardous Material) Anthracene IL Benzo(a)anthracene IL Benzo(a)pyrene IL Benzo(b)fluoranthene IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene IL IL Benzoic acid IL Benzyl alcohol bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chrysene IL IL Dibenz(a,h) anthracene Dibenzofuran IL IL Diethyl phthalate Dimethyl phthalate IL Di-n-butyl phthalate IL Di-n-octyl phthalate IL Fluoranthene IL Fluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL Hexachlorocyclopentadiene IL Hexachloroethane IL Indeno(1,2,3-cd) pyrene IL Isophorone IL Naphthalene IL Nitrobenzene IL n-Nitrosodiethylamine IL n-Nitrosodimethylamine IL n-Nitrosodi-n-propylamine IL n-Nitrosodiphenylamine IL IL n-Nitrosomethylethylamine Pentachlorobenzene IL Pentachlorophenol IL Phenanthrene IL Phenol IL Pyrene IL **Pyridine** IL Method EPA 8270C Mod LVI Acetochlor IL Alachlor IL **Atrazine** IL Butylate IL Cyanazine IL EPTC (Eptam, s-ethyl-dipropyl thio carbamate) IL Metolachlor IL Metribuzin IL IL Pendimethalin (Penoxalin)

Simazine

IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Solid & Hazardous Material) Trifluralin (Treflan)	IL
Method EPA 9012A Rev: 1 Cyanide	IL
Method EPA 9014 Rev: 0 Cyanide	IL
Method EPA 9020B Rev: 2 Total organic halides (TOX)	IL
Method EPA 9023 Rev: 0 Extractable organics halides (EOX)	IL
Method EPA 9034 Rev: 0 Sulfide	IL
Method EPA 9036 Rev: 0 Sulfate	IL
Method EPA 9045C Rev: 3 pH	IL
Method EPA 9060A Total organic carbon	IL
Method EPA 9065 Rev: 0 Total phenolics	IL
Method EPA 9214 Rev: 0 Fluoride	IL

Field of Testing /Matrix: SDWA (Potable Water)	
Method EPA 180.1 Rev: 2	
Turbidity	IL
Method EPA 200.7 Rev: 4.4	
Aluminum	IL
Barium	IL
Beryllium	IL
Boron	īL
Cadmium	IL
Calcium	IL
Chromium	IL
Copper	IL
Iron	IL
Magnesium	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Potassium	IL
Silver	IL
Sodium	IL
Vanadium	IL
Zinc	IL
Method EPA 200.8 Rev: 5.4	
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Cadmium	IL
Chromium	IL
Copper	IL
Lead	IL
Manganese	IL
Molybdenum	IL
Nickel	IL "
Selenium	IL "
Silver	IL "
Thallium	IL IL
Zinc	IL
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 335.4 Rev: 1	
Cyanide	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Method SM 2130 B Rev: 20th ED	
Turbidity	IL
Method SM 2320 B Rev: 23rd ED	
Alkalinity as CaCO3	IL
Method SM 2340 B Rev: 23rd ED	,_
Hardness	IL
i iaiuness	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: SDWA (Potable Water)	
Method SM 2510 B Rev: 21st ED Conductivity	IL
Method SM 2540 C Rev: 23rd ED Total dissolved solids	IL
Method SM 4500-CI G Rev: 20th ED Total chlorine	IL
Method SM 4500-F C Rev: 23rd ED Fluoride	IL
Method SM 4500-H+ B Rev: 21st ED pH	IL
Method SM 4500-NO2 B Rev: 23rd ED Nitrite	IL
Method SM 4500-P E Rev: 23rd ED Orthophosphate as P	IL
Method SM 4500-SiO2 D Rev: 23rd ED Silica as SiO2	IL
Method SM 5310 C Rev: 21st ED Dissolved organic carbon (DOC) Total organic carbon	IL IL
End of Scope of Accreditation	