REPORT OF DRINKING WATER SAMPLING FOR LEAD CONTENT AT:

DISCOVERY RIDGE 2523 SOMMERS RD LAKE SAINT LOUIS, MISSOURI 63367



PREPARED FOR:

MRS. ANGELA HAWKINS
DIRECTOR OF MAINTENANCE
WENTZVILLE R-IV SCHOOL DISTRICT
101 SUPPORT SERVICE DRIVE
WENTZVILLE, MISSOURI 63385

PREPARED BY:

J.S. HELD, LLC #6 MEADOW HEIGHTS PROFESSIONAL PARK COLLINSVILLE, ILLINOIS 62234 (618) 343-3590

OCTOBER 2023

DOCUMENT TO BE RETAINED INDEFINITELY

TABLE OF CONTENTS

23-0-448
Drinking Water Sampling for Lead
Wentzville R-IV School District
Discovery Ridge
2523 Sommers Rd
Lake Saint Louis, Missouri 63367

EXECUTIVE SUMMARY

APPENDIX A	Sample Locations/Results
APPENDIX B	Laboratory Analysis
ADDENIDIV C	Cradantiala

EXECUTIVE SUMMARY



6 Meadow Heights Professional Park Drive Collinsville, IL 62234 | US

jsheld.com

November 8th, 2023

Mrs. Angela Hawkins Director of Maintenance Wentzville R-IV School District 101 Support Service Drive Wentzville, Missouri 63385

Subject: Results of Drinking Water Testing for Lead Content

Site(s): Discovery Ridge

2523 Sommers Rd

Lake Saint Louis, Missouri 63367

Dear Mrs. Hawkins

On the morning of October 24th, 2023, J.S. Held (JSH) performed lead testing of multiple water sources at the Discovery Ridge located at 2523 Sommers Rd, Lake Saint Louis, Missouri. The sampling was performed by trained and licensed personnel in accordance with USEPA, HUD and State of Missouri Regulations and Guidelines. Work was performed in accordance with the newly amended Missouri Senate Bill 681.

All inspectors involved with sampling activities had EPA approved training in lead. Certifications for our firm and the inspector collecting the samples are included as Appendix C to this document.

All samples were collected on a "first draw" and "second draw" basis. "First draw" is achieved by allowing the water system to rest for at least eight hours prior to sampling in order to collect any existing debris or settlement within the sample. The intent of this sampling is to replicate "worst case scenario" conditions. JSH proposes to collect a second sample from each source as a "follow-up sample" per the Missouri Senate Bill 681 requirements. As such, JSH inspectors met at the school at 5:00 a.m. to collect water samples before the systems were used by staff or students. The State of Missouri and other regulatory agencies recommend that water sources run for at least thirty seconds and as long as two minutes prior to use to avoid settling within the water system.

Drinking water samples were collected from Forty-Seven (47) different locations throughout Discovery Ridge during the sampling event. The water samples were collected from drinking fountains and sinks potentially utilized for cooking or drinking activities at the campus. After sample collection, samples were immediately iced down and delivered to Teklab, Inc. located in Collinsville, Illinois following strict chain of custody procedures. Teklab is a NELAP accredited and State of Illinois licensed laboratory specializing in drinking water analysis. Detailed sampling locations and sample results are located in Appendix A of this report.

The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 micrograms per liter (µg/L). The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 microgram of lead per liter (µg/L). This reporting value equates to 1.0 parts per billion (ppb) of lead. The USEPA action level for lead in drinking water is 15.0 ppb for PSW. The USEPA document titled "Lead in Drinking Water at Schools and Child Care Facilities" last updated November 9, 2015 identifies an action level for drinking water collected from a plumbing fixture as 20.0 ppb. Ninety-Two (92) samples collected from the selected locations at the Discovery Ridge reported sample results which were less than the action level. This information can be found under the National Primary Drinking Water Regulations provided by the EPA, CFR 2010 Title 40. (See Appendix A and B for Sample Results) The Missouri Senate Bill 1075 require potable plumbing fixtures to be less than 5.0 ppb, the levels area above 5 ppb, then action shall be necessary to filter the water from the fixture or clean/repair/replace the fixture and retest until the levels are reported below 5 ppb.

All samples collected from the selected locations at Discovery Ridge Elementary School were less than the 5 ppb requirements under Senate Bill 681. The district will be required to provide notification to parents and staff within 7 days of receiving these sample results and results shall be posted on the district website within 2 weeks. Any samples reported over 5 ppb should be re-sampled on an annual basis at a minimum.

Although no samples were identified above the action level, JSH recommends that all water sources run for at least thirty seconds prior to use as recommended by the USEPA.

Page 3 Mrs. Hawkins November 8th, 2023

JSH is pleased to provide this information to Wentzville R-IV School District and we appreciate the opportunity to provide quality environmental consulting services. Please call us at (618) 343-3590 if you have any questions or to arrange a meeting to discuss.

Sincerely, J.S. Held, LLC

Jim Yasitis

Jim Yasitis

Vice President of Environmental Health & Safety

APPENDIX A SAMPLE LOCATIONS & RESULTS

TABLE 1

Drinking Water Sampling for Lead Content Wentzville R-IV School District Discovery Ridge Elementary School

Sampled: October 24, 2023

Samp	ole ID Location	Water Source	Results (ppb)
01A	Kitchen- Single Bay	Sink	<1.0
01B	Kitchen- Single Bay	Sink	<1.0
02A	Kitchen- Dishwashing Sprayer	Sink	1.3
02B	Kitchen- Dishwashing Sprayer	Sink	<1.0
03A	Kitchen- 3 Bay (Left) Dishwashing Sprayer	Sink	<1.0
03B	Kitchen- 3 Bay (Left) Dishwashing Sprayer	Sink	<1.0
04A	Kitchen- 3 Bay (Right)	Sink	<1.0
04B	Kitchen- 3 Bay (Right)	Sink	<1.0
05A	Kitchen- 2 Bay	Sink	<1.0
05B	Kitchen- 2 Bay	Sink	<1.0
06A	Kitchen- Pot Filler	Sink	<1.0
06B	Kitchen- Pot Filler	Sink	<1.0
07	Kitchen- Ice Machine	Ice Machine	<1.0
08A	Near Room C4 (Left)	Fountain	<1.0
08B	Near Room C4 (Left)	Fountain	<1.0
09A	Near Room C4 (Left Center)	Fountain	<1.0
09B	Near Room C4 (Left Center)	Fountain	<1.0
10A	Near Room C4 (Right Center)	Fountain	<1.0
10B	Near Room C4 (Right Center)	Fountain	<1.0
11A	Near Room C4 (Right)	Fountain	<1.0
11B	Near Room C4 (Right)	Fountain	<1.0
12A	Room C11	Sink	<1.0
12B	Room C11	Sink	<1.0
13A	Room C10	Sink	<1.0
13B	Room C10	Sink	<1.0
14A	Room C12	Sink	<1.0
14B	Room C12	Sink	<1.0
15A	Room C13	Sink	<1.0
15B	Room C13	Sink	<1.0
16A	Near Room C12 (Left)	Fountain	<1.0
16B	Near Room C12 (Left)	Fountain	<1.0
17A	Near Room C12 (Right)	Fountain	<1.0
17B	Near Room C12 (Right)	Fountain	<1.0
18A	Near Room C11 (Left)	Fountain	<1.0
18B	Near Room C11 (Left)	Fountain	<1.0

Samp	ole ID Location	Water Source	Results (ppb)
19A	Near Room C11 (Right)	Fountain	<1.0
19B	Near Room C11 (Right)	Fountain	<1.0
20A	Near Room C26 (Left)	Fountain	<1.0
20B	Near Room C26 (Left)	Fountain	<1.0
21A	Near Room C26 (Left Center)	Fountain	<1.0
21B	Near Room C26 (Left Center)	Fountain	<1.0
22A	Near Room C26 (Right Center)	Fountain	<1.0
22B	Near Room C26 (Right Center)	Fountain	<1.0
23A	Near Room C26 (Right)	Fountain	<1.0
23B	Near Room C26 (Right)	Fountain	<1.0
23B 24A	Near Room C2 (Left)	Fountain	<1.0
24A 24B	Near Room C2 (Left)	Fountain	<1.0
25A	Near Room C2 (Left Center)	Fountain	<1.0
25A	Near Room C2 (Left Center)	Fountain	<1.0
25B 26A	Near Room C2 (Right Center)	Fountain	<1.0
26B	Near Room C2 (Right Center)	Fountain	<1.0
20B 27A	Near Room C2 (Right)	Fountain	<1.0
27B	Near Room C2 (Right)	Fountain	<1.0
28A	Room A5 Teacher's Lounge	Sink	<1.0
28B	Room A5 Teacher's Lounge	Sink	<1.0
29 29	Room A5 Teacher's Lounge	Ice Machine	<1.0
30A	Room A6 Nurses Office	Sink	<1.0
30B	Room A6 Nurses Office	Sink	<1.0
31A	Near Room E1 (Left)	Fountain	<1.0
31B	Near Room E1 (Left)	Fountain	<1.0
32A	Near Room E1 (Left Center)	Fountain	<1.0
32B	Near Room E1 (Left Center)	Fountain	<1.0
33A	Near Room E1 (Right Center)	Fountain	<1.0
33B	Near Room E1 (Right Center)	Fountain	<1.0
34A	Near Room E1 (Right)	Fountain	<1.0
34B	Near Room E1 (Right)	Fountain	<1.0
35A	Near Room D2 (Left)	Fountain	<1.0
35B	Near Room D2 (Left)	Fountain	<1.0
36A	Near Room D2 (Left Center)	Fountain	<1.0
36B	Near Room D2 (Left Center)	Fountain	<1.0
37A	Near Room D2 (Right Center)	Fountain	<1.0
37B	Near Room D2 (Right Center)	Fountain	<1.0
38A	Room DB2	Sink	<1.0
38B	Room DB2	Sink	<1.0
39A	Near Room D2 (Right)	Fountain	<1.0
39B	Near Room D2 (Right)	Fountain	<1.0
40A	Near Room E3 (Left)	Fountain	<1.0
40B	Near Room E3 (Left)	Fountain	<1.0
41A	Near Room E3 (Left Center)	Fountain	<1.0
41B	Near Room E3 (Left Center)	Fountain	<1.0

Samp	le ID Location	Water Source	Results (ppb)
42A	Near Room E3 (Right Center)	Fountain	<1.0
42B	Near Room E3 (Right Center)	Fountain	<1.0
43A	Near Room E3 (Right)	Fountain	<1.0
43B	Near Room E3 (Right)	Fountain	<1.0
44A	Near Room F21A (Left)	Fountain	<1.0
44B	Near Room F21A (Left)	Fountain	<1.0
45A	Near Room F21A (Left Center)	Fountain	<1.0
45B	Near Room F21A (Left Center)	Fountain	<1.0
46A	Near Room F21A (Right Center)	Fountain	<1.0
46B	Near Room F21A (Right Center)	Fountain	<1.0
47A	Near Room F21A (Right)	Fountain	<1.0
47B	Near Room F21A (Right)	Fountain	<1.0



Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.



Water source is 5-19.9 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum.

Sample Legend

[&]quot;A" = First Draw

[&]quot;B" = Second Draw

DISCOVERY RIDGE ELEMENTARY SCHOOL

APPENDIX B LABORATORY ANALYSIS



November 07, 2023

Jim Yasitis Environmental Consultants, LLC #6 Meadow Heights Professional Park

Collinsville, IL 62234 TEL: (618) 343-3590 FAX: (618) 343-3597

RE: Wentzville SD Water Sampling 231000104-Disc

Ridge

Dear Jim Yasitis:

TEKLAB, INC received 60 samples on 10/24/2023 10:19:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marvin L. Darling Project Manager

(618)344-1004 ex 41

mdarling@teklabinc.com

Mowin L. Darling I



WorkOrder: 23101948

Illinois 100226 Kansas E-10374 Louisiana 05002 Louisiana 05003 Oklahoma 9978



Report Contents

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
 - DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
 - DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

http://www.teklabinc.com/

Report Date: 07-Nov-23

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge

Qualifiers

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948
Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

Cooler Receipt Temp: N/A °C

Locations

	Collinsville		Springfield	Kansas City					
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road				
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214				
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998				
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998				
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com				
	Collinsville Air		Chicago						
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.						
	Collinsville, IL 62234-7425		Downers Grove, IL 60515						
Phone	(618) 344-1004	Phone	(630) 324-6855						
Fax	(618) 344-1005	Fax							
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com						



Accreditations

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual			Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	, 200.8 R5.4, META	LS BY ICPMS (TOTAL)						
Lead								
23101948-001	A 01A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:38	10/24/2023 3:00
23101948-002/	A 01B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 14:42	10/24/2023 3:00
23101948-003/	A 02A	NELAP	1.0	1.3	μg/L	1	11/03/2023 14:46	10/24/2023 3:00
23101948-004	A 02B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:02	10/24/2023 3:00
23101948-005/	A 03A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:30	10/24/2023 3:00
23101948-006	A 03B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:06	10/24/2023 3:00
23101948-007/	A 04A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:10	10/24/2023 3:00
23101948-008/	A 04B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:14	10/24/2023 3:00
23101948-009/	A 05A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:18	10/24/2023 3:00
23101948-010/	A 05B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:22	10/24/2023 3:00
23101948-011/	A 06A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 15:26	10/24/2023 3:00
23101948-012/	A 06B	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:15	10/24/2023 3:00
23101948-013/	A 07	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:19	10/24/2023 3:00
23101948-014	A 08A	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:23	10/24/2023 3:00
23101948-015/	A 08B	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:43	10/24/2023 3:00
23101948-016	A 09A	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:27	10/24/2023 3:00
23101948-017/	A 09B	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:31	10/24/2023 3:00
23101948-018	A 10A	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:35	10/24/2023 3:00
23101948-019/	A 10B	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 8:39	10/24/2023 3:00
23101948-020	A 11A	NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:07	10/24/2023 3:00
23101948-021		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:11	10/24/2023 3:00
23101948-022/		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:15	10/24/2023 3:00
23101948-023/		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:19	10/24/2023 3:00
23101948-024		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:23	10/24/2023 3:00
23101948-025/		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:35	10/24/2023 3:00
23101948-026		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:27	10/24/2023 3:00
23101948-027		NELAP	1.0	< 1.0	μg/L	1	11/06/2023 9:31	10/24/2023 3:00
23101948-028		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 17:40	10/24/2023 3:00
23101948-029/		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 17:44	10/24/2023 3:00
23101948-030		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 17:48	10/24/2023 3:00
23101948-031		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 17:52	10/24/2023 3:00
23101948-032		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 17:56	10/24/2023 3:00
23101948-033/		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:00	10/24/2023 3:00
23101948-034		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:04	10/24/2023 3:00
23101948-035/		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:08	10/24/2023 3:00
23101948-036		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:33	10/24/2023 3:00
23101948-037		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:37	10/24/2023 3:00
23101948-038		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:41	10/24/2023 3:00
23101948-039		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:45	10/24/2023 3:00
23101948-040		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:49	10/24/2023 3:00
23101948-041		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:53	10/24/2023 3:00
23101948-042		NELAP	1.0	< 1.0	μg/L	1	11/03/2023 18:57	10/24/2023 3:00
23101948-042/		NELAP	1.0	< 1.0	μg/L μg/L	1	11/03/2023 10:01	10/24/2023 3:00
23101948-044		NELAP	1.0	< 1.0	μg/L μg/L	1	11/03/2023 19:01	10/24/2023 3:00
23101948-044/		NELAP	1.0	< 1.0 < 1.0	μg/L μg/L	1	11/03/2023 19:03	10/24/2023 3:00
23101948-045/		NELAP	1.0	< 1.0 < 1.0		1	11/03/2023 20:02	10/24/2023 3:00
23101948-047		NELAP	1.0	< 1.0 < 1.0	μg/L μg/l	1	11/03/2023 19:09	10/24/2023 3:00
23101948-0477		NELAP	1.0	< 1.0 < 1.0	μg/L μg/L	1	11/03/2023 19:34	10/24/2023 3:00
20101040/	. 20/1	I TLL/ U	1.0	< 1.0	⊬ 9/∟	'		10/24/2023 3.00



Laboratory Results

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101948

Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	4, 200.8 R5.4, META	LS BY ICPMS (TOTAL)						
Lead								
23101948-049	A 25B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 19:42	10/24/2023 3:00
23101948-050	A 26A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 19:46	10/24/2023 3:00
23101948-051	A 26B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 19:50	10/24/2023 3:00
23101948-052	A 27A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 19:54	10/24/2023 3:00
23101948-053	A 27B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 19:58	10/24/2023 3:00
23101948-054	A 28A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 20:27	10/24/2023 3:00
23101948-055	A 28B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 20:55	10/24/2023 3:00
23101948-056	A 29	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 20:31	10/24/2023 3:00
23101948-057	A 30A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 20:35	10/24/2023 3:00
23101948-058	A 30B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:17	10/24/2023 3:00
23101948-059	A 31A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:21	10/24/2023 3:00
23101948-060	A 31B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:25	10/24/2023 3:00



Receiving Check List

http://www.teklabinc.com/

Work Order: 23101948 Client: Environmental Consultants, LLC Client Project: Wentzville SD Water Sampling 231000104-Disc Ridge Report Date: 07-Nov-23 Carrier: Devon Rathbun Received By: AMD Completed by: Reviewed by: mbor Ollacuc On: On: 25-Oct-23 25-Oct-23 Amber Dilallo Ellie Hopkins Extra pages included 0 Pages to follow: Chain of custody Shipping container/cooler in good condition? Yes **V** No 🗔 Not Present Temp °C N/A Type of thermal preservation? **V** Ice _ Blue Ice None Dry Ice Chain of custody present? **~** No L Yes Chain of custody signed when relinquished and received? **~** Yes No L **~** Chain of custody agrees with sample labels? No 🗀 Yes **~** Samples in proper container/bottle? Yes No 🗀 **V** Sample containers intact? Yes No Yes **~** No Sufficient sample volume for indicated test? **~** No \square All samples received within holding time? Yes NA 🗸 Field Lab 🗌 Reported field parameters measured: Yes 🗸 No \square Container/Temp Blank temperature in compliance? When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected. Water - at least one vial per sample has zero headspace? Yes 🗌 No 🗀 No VOA vials 🗸 No TOX containers Water - TOX containers have zero headspace? Yes No 🗌 Yes 🗹 No 🗌 Water - pH acceptable upon receipt? NA 🗸 NPDES/CWA TCN interferences checked/treated in the field? Yes No \square

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 10/25/2023 9:07:26 AM

Any No responses must be detailed below or on the COC.

CHAIN OF CUSTODY pg. 1 of 10 Work Order \$230 946

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005 Samples on: Elice D Blue Le Vi Noice LA "C J.S. Held Client: Preserved in: N Lab | El Field | FOR LAB USE ONLY 6 Meadow Heights Prof Park Address: City | State | Zip: Collinsville, IL 6.2234 Contact: Jim Vasitis Phone: 618-343-3590 E-Mail: james. yasitis@jsheld.com Fax: 618-343-3597 Comments: Discovery Riege Elementory 2009 E Are these samples known to be hazardous? ☐ Yes ☑ No. Are there any required reporting limits to be met on the requested analysis? If yes, please provide Please report in ppb. limits in comment section. MYes \(\sim \) No INDICATE ANALYSIS REQUESTED Sample Collector's Name Project Name / Number MATRIX Wentzuille SD Water Sampling Brad Frisch 231000104 Results Requested Billing Instructions # and Type of Containers Drinking V Soil ☑ Standard ☐ 1-2 Day (100% Surcharge) Sludge NAO: NAOH HZSO2 HCL MeOH ☐ Other ☐ 3 Day (50% Surcharge) Other Lab Use Only Sample Identification | Date/Time Sampled 23601946 OIA. (0-24-23 3:00 AM X AL OIR 03 OJA DOWN OLB 163A 033 04A 043 054 0513 Date / Time Relinguished By Received By Date / Time 1019 Devon Rathbun SMO 10-24-2023

CHAIN OF CUSTODY pg. 2 of 10 Work Order #23121949

Client: J. S. Held						J Bluel										
Address: 6 Meadow Heights Prof	Park	26	256040	din.		Laio	DFic	ud.	FOR	LAR	use c	dmey				
City State Zip: Collinsuille, IL 6.2234			b Nov)S;												
Contact: Jim Vasitis Phor	ne: 618-343-3590	_														
E-Mail: james. yasitis@jsheld.com Fax:	618-343-3597	n necessary	onnanei)		í	7.,	e Eiei	184 Z19 d	a P. V	22	9,7					
Are these samples known to be involved in litigation? If ye Are these samples known to be hazardous? □ Yes 图 Are there any required reporting limits to be met on the reclimits in comment section. 图 Yes □ No	lo	<i>д</i> а 140					ppb.									
Project Name / Number Sa	imple Collector's Name		MAT	rix			IA	IDICAT	EAN	ALYSI	SREC	QUES	TED)		
Wentzuille SD Water Sampling Brad	Frisch		(ter						000					No de carbonne de la	La Capital de la	
Results Requested Billing Instru			Water		9	(DW)								or contribution of the		
☑ Standard ☐ 1-2 Day (100% Surcharge)	NNPRES HNOs HCL	Į į	water Drinking	Soil	Waste						On the state of th					
□ Other □ 3 Day (50% Surcharge) Lab Use Only Sample Identification Date/Time		Taking the Control of	water	Soil	Sp.	ea	anno en				Capus (Cirpo Cirio)). Limited of the second of th			
			X			$\frac{1}{X}$			_	+			_	-	-	
	3:00 AM X .	_		 	-	$\frac{\lambda}{\chi}$.ei	-	-	 -		\dashv		-	
611 O6B									_		 					
016 07	1 1		<u> </u>	_		X		<u> </u>			-				_	
CM4 08A			-X,			X										
088	X		X			X										
O100 09A			X			X				_						
OD 09B			X			7							·			
is to A	γ		1			8	EL SAN DATABLE	990			,				.]	
og lob	<u> </u>		λ			X			, Additional of the second			a.po	.			
CIC II A	× ×		X		Ì	X							,		agent annual	
· · · Relinquished By	Date / Time		T	سلسك		Rece	ived By	<u></u>				Date	/Ti	ne		
Devon (Zathbun	10-24-2023		119v	ulQ	<u> </u>	101	DOLL				ohy	123		019	}	
	A SUMMAN AND A SUMAN AND A SUMMAN AND A SUMA												44-4-141			
	The state of the s													-		

pg. 3 of 10 Work Order # 23101948

Client: J.S. Hell											Jaan	ples	įΦį	1.		CO:		lue l	CQ.	I N	o Ica				°C			
Address: 6 Meadow Heig	hts	Prof Park	l e)res	GLA:	2(<u>)</u>	iki.	Ø	Lab		1 Fi	uld	Ī	OR:	LAB	use	OML	<u>Y</u>			
City State Zip: Collinsville, IL 6	22	34									.ab	Noi	96															
Contact: Jim Vasitis		Phone: _																										
E-Mail: james. yasitis@jsheld.com	27	Fax:	618-	343	-3.	597					300 }				ı	2 209	. 1	.		i dar		22	9,=					
Are these samples known to be involved in litigate these samples known to be hazardous? If Are there any required reporting limits to be millimits in comment section. 图 Yes □ No] Yes	M No			•		•		•							-10°3			rier									
Project Name / Number		Sample	e Coll	ect)r's	Nan	1e	•				MA"	rri	X				18	idic.	ate.	ANA	LYS	is re	QUE	STE	D		
Wentzuille SD Water Sampling 831000104	B	rad Fr	isch									(ter	No. (Protection	Official														
Results Requested Bill Standard D 1-2 Day (100% Surcharge)	lling	Instructio			dT	ype c	f Co	~~~	_			Drinking Water	a a company and a second		93	(DM)						No.	T remains the contract of the				-	
☐ Other ☐ 3 Day (50% Surcharge)		·		RES	3	I o		Ī	SO2	la:	Water	nkim		Sludge	Waste	Z							Lapin Lapaning de La					
Lab Use Only Sample Identification	Date	/Time Sam	pled	UNPRES		NaOH RzSO4	S	MeO	F	Other	Wa	ă	S	S	Š	rea												
Marian IIB.	しょ	4.23 3:00		X	1							X				X												
022 IZA				X								X				X										ļ		
023 13 B				x	·							X			-	X							<u> </u>					
34 13A				χ								X				X								-		ļ .	ļ	
O25 13 B				χ								X				X						_		-		ļ	ļ	
Ozio IMA				X			<u> </u>					X				X				<u> </u>	<u> </u>	 	 	ļ	ļ ·	<u> </u>	ļ	
027 148			-	X			_					X				7			<u> </u>	<u></u>	<u> </u>	-	-	-	<u> · </u>		<u></u>	ļ
C28 15A		·		Y								1		Ŀ	-	1			<u></u>						ļ	<u> </u>	<u> </u>	ļ
96 , 15B	1			X								区				X			ļ			ļ					<u> </u>	ļ
130 16 A		4	;	X				<u> </u>				X				X		<u> </u>	<u> </u>		<u> </u>		<u> </u>	<u> </u>		<u></u>	<u></u>	
Relinquished By	-		ور المراجعة	at the same	and the later of t	Tim	3		e Charles	-		and the second	نا ن سيدران .	lagranio Mi		mganten-car	eivec					بنب	·		te / T	ime		
Devon (Zathbun	·	to-,	24. 2c	<u>13</u>		des present the second	and the second		en i i i i i i i i i i i i i i i i i i i		_\(\)	M	ak		4_	Qi		ll	0	AT WATER STATE OF		11	Ope	4hi		<u> </u>	}	
		-	e en	t yf respirit stage							-	-		Page 1905	omputed			***************************************			-12.04						فالوليجة ومالا مجيعو	
	Y 	· .					-	- our a state of			_					Carlom between		epitele et announce				+-	· · · · · · · · · · · · · · · · · · ·	·				
					حتند						!_															*		

pg. 4 of 10 Work Order # 23101948

Client: J. S. Helk						100000	********	*****					Blue							°C			
Address: 6 Meadow Heigh	ts Prof Park				-	Ē	res	erve	d ii	li L	1 L.	lÖ.		igld	F	OR L	A8 1	<u>USE</u>	oml	V			
City / State / Zip: Collinsville, IL 6.	2234				-		ab l	ijak	15.														
Contact: Jim Vasitis	Phone: _6/8-	343-3	3590																				
E-Mail: james. yasitis@jsheld.com	Fax: <u>6/8</u>	618-343-3597						mor			8		Eu	Som Di	ı e a F	, L	? 2025)ē					
Are these samples known to be involved in litigate Are these samples known to be hazardous? Are there any required reporting limits to be meal limits in comment section.		-				* 188							<u>ppb.</u>										
Project Name / Number Westzuille SD Water Sampling	Sample Col	lector'	s Nam	e ·			Ī	TAN	RIX	{			· ocenny ocenny	NDIC.	ATE.	ANA	LYSI	S RE	QUE	STE)		
23/000104	Brad Frisch							ofter.	-Carrierativa	ACTIVIDATE OF THE PARTY.	-		- CONTRACTOR				And the second second	o beginner og de		Anny of the same	of the same independent	la constitución de la constituci	
Results Requested Billi ☑ Standard ☐ 1-2 Day (100% Surcharge)		# and						D We	Coloniana	69		(m)	and throat dispute				***************************************						
☐ Other ☐ ☐ 3 Day (50% Surcharge)		UNPRES HNO3	FO		1504	Je Je	Water	Orinking Water	100	Studge	, veca	Lead					and the second				- Andrews		
	Date/Time Sampled	SE	Na(N2S	Z Z	TE Z	50	M	à	8	\$ 6	<u>.</u>	87											
231 1943, 16B		X						X				X											
53L 17A	f I	X						X				X			."							ogethers, and the second	
33 17B	`	χ						X				X										,	
34 18A		χ						χ				X										····	
∵ 18B °		X						X				X											
036 19 A		χ						X				K			<u> </u>	ļ							ļ
37 19B		X						X				7			<u> </u>		<u> </u>			·			
Z\$ 20A		Y						1				1							-		<u>.</u>		<u></u>
U39 20B	<i>λ</i> ,	X						入				K								<u></u>			
C45 21A	A 9	Х		ŀ				X				X											
Relinquished By		Date	/Time								R	lecei	ved 8	9					Dat	e/T			
Devon Rathbun	10-24.2	७३३							10	4	Qı	ناك	مال	>	STATE OF THE PARTY OF	ent-carridae-manatar	كليا	2/LL	she		1019	1_	
		•			na Rocal Constitution		_			armaildadiii		A TAXABLE STATE				0,04		allander of the same	درستان التوريسان	transfer de la companya de la compa			
ļ			·	-		·wKwejr-whe				······································			nggying gangini Sasa		·		 	·					
																	<u> </u>						

pg. <u>5</u> of <u>10</u> Work Order * 23101941

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005

Samples on: Elice E Blue ice E No Foz

Address: 6 Meadow Height	s Prof Park			edervedin: L	O'Lab O'Field FOR	LAB USE ONLY				
City State Zip: Collinsville, IL 6.2	234			d Noves:						
Contact: Jim Yasitis	Phone: 6/8-	343-3590								
E-Mail: james, yasitis@jsheld.com	Fax: 618-	343-3597		mments:	Riege Elemenner	219=				
e Are these samples known to be involved in litigation Are these samples known to be hazardous? □ You Are there any required reporting limits to be met to limits in comment section. 图 Yes □ No	es M No on the requested anal	ysis? If yes, please	e provide ρ/c	ese refor	t in ppb.					
Project Name / Number Wentzuille SD Water Sampling	lector's Name		MATRIX		ALYSIS REQUESTED					
231000104	Brad Frisch			, iter						
Results Requested Billin	ng Instructions	# and Type of Co		Drinking Water Soil Sludge						
☐ Other ☐ 3 Day (50% Surcharge)		Unpres Hno: Naoh H2SO: HCL	MeOH NaMSO4 Other	iking dge	A A A A A A A A A A A A A A A A A A A					
Lab Use Only Sample Identification Da	ate/Time Sampled	UNPRE HNO3 H2SO4 HCL	MeOH NaHSO Other		rea.					
04004000000000000000000000000000000000		<i>X</i> .		X .	X					
042 22 A		XIII		X	X	·				
CH2 27B		$ \chi $		X	X					
Q4U 23 A		X		X	X					
OHS 23B		X		x	X					
CARE 24A		χ		x	X					
047 248		χ I		X	7					
CHI 2SA		Υ		. 8						
OUG 25.3	1	χ [†]		χ	X					
264	7 9	У		X	X	·				
Relinquished By		Date / Time			Received By	Date / Time				
Devon (Zathbun)	10-24-20	923		10ma	Ollalla	10hyps 1019.				
The individual signing this games to the letter	STATE OF THE PARTY									

J.S. Held

Client:

pg. 6 of 10 Work Order # 2310948

Client: J. S. Held							Sau	nple	so	n. I	34	t:0 i	I BN	ig içe		No Ic	Ž.			e6			
Address: 6 Meadow Heights Prof Park							Pre	eer	red	10:	131	-016.		field		FOR	LAR	USE	ONL	<u> </u>			
City State Zip: Collinsuille, IL 622.	34						La.	o Mo	1005														
Contact: Jim Vasitis Phone: 618-343-3590																							
E-Mail: james. yasitis@jsheld.com Fax: 618-343-3597							ronav)			ı f	7	. 15	ıEm.	e de la composition della comp	ji v	22	9,=						
Are these samples known to be involved in litigation Are these samples known to be hazardous? 口 Yes Are there any required reporting limits to be met on the limits in comment section. 图 Yes 口 No	M No he requested ana	ysis?	lf yes,	pleas	e pro																		
Project Name / Number Sample Collector's Name Wentzuille SD Water Sampling Brad Fried						MATRIX					INDI	CATE	ANA	IL YSI	is re	QUE	STE)	7				
231000104	rad Frisch							ie.						Pediatrocka	Potential	-						Transport	
Results Requested Billing	nstructions	# and				CHARLES THE PARTY NAMED IN	current !	a Wa			93	(md)	Design sections		y g principalism								
☐ Other ☐ ☐ 3 Day (50% Surcharge)	·	RES	E E	5 .	MeOH	200	Wee.	Drinking Water	ESEL	Sludge	Was	rg.	ant necessary and the	e de la constante de la consta	ored Establish	*Object of the state of the sta			10 A C T T T T T T T T T T T T T T T T T T		en franches		
Lab Use Only Sample Identification Date	Time Sampled	UNPRES HNO3 NaOH HzSO4		Med	R S		à	So	ŝ	S	Lea												
731019851 26B W24	123 3:00 AM	X	1.					X				X		Table of Table	/								
OS2 27A		X						X				X			.21								•
OS2 27B		X						X				X											
DBU 28A		χ						·χ				χ											
35 28B		χ						X				X											
29. 29.		X						X				X				_			ļ				
<u> </u>		X						<u> X</u>				7							-	·			
30 B		Υ						l			·	7										,	
050 31A J		X						<u> </u>				X							en nuberen ett Skot				
OLGO 31B	4	Х						X				X											
Relinquished By			e / Tip	ne								mentermunicus.	ived		and a section of the		marries		-	e/T	<u> </u>		
Devon Rathbun	10-24-20	ルシュュ		ton Convey	Marine and an and an			V	M	_	1 (July	ol	لي	THE PROPERTY OF THE PROPERTY O	all sparsely party, agencies	15	Shr	th3		1019	'	
·			and the second second second	1452 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444 - 1444	and the second second	-	- Anna Cara					-constitution			****	ressie izz alan e, me y dan	_			·····			
					-0	-									National State of State of		-						
The individual circumstation of the state of																							

100226

E-10374

05002

05003

9978

Illinois

Kansas

Louisiana

Louisiana

Oklahoma



November 06, 2023

Jim Yasitis Environmental Consultants, LLC #6 Meadow Heights Professional Park

Collinsville, IL 62234 TEL: (618) 343-3590 FAX: (618) 343-3597

PRORATORY

WorkOrder: 23101949

RE: Wentzville SD Water Sampling 231000104-Disc.

Ridge

Dear Jim Yasitis:

TEKLAB, INC received 32 samples on 10/24/2023 10:19:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marvin L. Darling Project Manager

(618)344-1004 ex 41

mdarling@teklabinc.com

Mowin L. Darling I



Report Contents

http://www.teklabinc.com/

Client: Environmental Consultants, LLC

Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge

Report Date: 06-Nov-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge Report Date: 06-Nov-23

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
 - DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
 - DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge Report Date: 06-Nov-23

Qualifiers

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge Report Date: 06-Nov-23

Cooler Receipt Temp: N/A °C

Locations

	Collinsville		Springfield	Kansas City						
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road					
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214					
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998					
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998					
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com					
	Collinsville Air		Chicago							
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.							
	Collinsville, IL 62234-7425		Downers Grove, IL 60515							
Phone	(618) 344-1004	Phone	(630) 324-6855							
Fax	(618) 344-1005	Fax								
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com							



Accreditations

http://www.teklabinc.com/

Client: Environmental Consultants, LLC Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge Report Date: 06-Nov-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

http://www.teklabinc.com/

Report Date: 06-Nov-23

Client: Environmental Consultants, LLC Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	, 200.8 R5.4, META	LS BY ICPMS (TOTAL)						
Lead	,	,						
23101949-001	A 32A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:28	10/24/2023 3:00
23101949-002	A 32B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:32	10/24/2023 3:00
23101949-003	A 33A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:43	10/24/2023 3:00
23101949-004	A 33B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:47	10/24/2023 3:00
23101949-005	A 34A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 9:50	10/24/2023 3:00
23101949-006	A 34B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:14	10/24/2023 3:00
23101949-007	A 35A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:17	10/24/2023 3:00
23101949-008	A 35B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:21	10/24/2023 3:00
23101949-009	A 36A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:25	10/24/2023 3:00
23101949-010	A 36B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:28	10/24/2023 3:00
23101949-011	A 37A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:32	10/24/2023 3:00
23101949-012	A 37B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:36	10/24/2023 3:00
23101949-013	A 38A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 5:47	10/24/2023 3:00
23101949-014	A 38B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:01	10/24/2023 3:00
23101949-015	A 39A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:05	10/24/2023 3:00
23101949-016	A 39B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:09	10/24/2023 3:00
23101949-017	A 40A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:12	10/24/2023 3:00
23101949-018	A 40B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:16	10/24/2023 3:00
23101949-019	A 41A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:20	10/24/2023 3:00
23101949-020	A 41B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:23	10/24/2023 3:00
23101949-021	A 42A	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:27	10/24/2023 3:00
23101949-022	A 42B	NELAP	1.0	< 1.0	μg/L	1	11/04/2023 6:31	10/24/2023 3:00
23101949-023	A 43A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:44	10/24/2023 3:00
23101949-024	A 43B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:48	10/24/2023 3:00
23101949-025	A 44A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:51	10/24/2023 3:00
23101949-026	A 44B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:55	10/24/2023 3:00
23101949-027	A 45A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 11:59	10/24/2023 3:00
23101949-028	A 45B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:02	10/24/2023 3:00
23101949-029	A 46A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:06	10/24/2023 3:00
23101949-030	A 46B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:10	10/24/2023 3:00
23101949-031	A 47A	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:13	10/24/2023 3:00
23101949-032	A 47B	NELAP	1.0	< 1.0	μg/L	1	11/03/2023 12:28	10/24/2023 3:00



Client: Environmental Consultants, LLC

Receiving Check List

http://www.teklabinc.com/

Work Order: 23101949

Client Project: Wentzville SD Water Sampling 231000104-Disc. Ridge Report Date: 06-Nov-23 Carrier: Employee Received By: AMD Completed by: Reviewed by: mbor Dilalla On: On: 25-Oct-23 25-Oct-23 Amber Dilallo Ellie Hopkins Extra pages included Pages to follow: Chain of custody 3 Shipping container/cooler in good condition? Yes **✓** No 🗔 Not Present Temp °C N/A Type of thermal preservation? **V** Ice _ Blue Ice None Dry Ice Chain of custody present? **~** No L Yes Chain of custody signed when relinquished and received? **~** Yes No L **~** Chain of custody agrees with sample labels? No 🗀 Yes **~** Samples in proper container/bottle? Yes No 🗀 **V** Sample containers intact? Yes No Yes **~** No Sufficient sample volume for indicated test? **~** No \square All samples received within holding time? Yes NA 🗸 Field Lab 🗌 Reported field parameters measured: Yes 🗸 No \square Container/Temp Blank temperature in compliance? When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected. Water - at least one vial per sample has zero headspace? Yes 🗌 No 🗀 No VOA vials 🗸 No TOX containers Water - TOX containers have zero headspace? Yes No 🗌 Yes 🗹 No 🗌 Water - pH acceptable upon receipt? NA 🗸 NPDES/CWA TCN interferences checked/treated in the field? Yes No 🗀 Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 10/25/2023 9:10:03 AM

pg. Z of 10 Work Order #23101949

Client: J. S. Held							alian)	ples	φħ	ı, E] [[e I	3 BW	e los	X, i	lo Ica		M	L.	ag:			
Address: 6 Meadow Heights Prof Park) Tes	GLAC	ct i	n:	31	alo	O	Field		FOR:	LAB	use	ONL	Ľ			
City State Zip: Collinsville, IL 6223	4						.ab l	Nob	18,														
Contact: Jim Vasitis Phone: 618-343-3590																							
E-Mail: james. yasitis@jsheld.com Fax: 618-343-3597						ĵon D				p	,	. 17	Eme	10 4 5 1	, , , , ,	20	9,=						
Are these samples known to be involved in litigation? If yes, a surcharge will apply. □ Yes □ No Are these samples known to be hazardous? □ Yes □ No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in comment section. □ Yes □ No				.,0																			
Project Name / Number Sample Collector's Name						MAT	RD	K_				INDIC	ate	ANA	LYSI	SRE	QUE	STE	2				
Wentzville SD Water Sampling Br. 231000104	ad Frisch							iteir		(COCOCOCO)			-	TACIDA DE LA COLONIA DE LA COL						n_months advised	and the second second	as Magazina da Paris	
Results Requested Billing Ir	structions		Туре					3 We	Age of Performance of the		93	(DM)		Participant of the Company of the Co	Personal Parties (ACE)	a del Carrier de la carrier de							
☑ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)	•	S E	NaOH	5/2	I C	Nario Carer	Water	Drinking Water	Soil	ව්ට්ල	8	~		consciperation	er-der distriction of the second					A) In Property Control	(Paragental Andrews)		
Lab Use Only Sample Identification Date/1	Time Sampled		OEZ	NO N	NeO 2		Wa	Ori	80	No.	Sp.	Lea	TO ALL PROPERTY OF THE PARTY OF	N A A A A A A A A A A A A A A A A A A A	and the second second	ero linearitante d'a				-	A Property Control of the Control of		
23101914 32 A 6024	23 3:00 AM	X	1. 1	1				X			Î	X		The state of the s	1								
002 32B		X	11					X				X			.ei								
003 33A		χ	11					X				K											
ON 33B		X	11	7	П		Î	X				χ											
0534A		X						χ				X											
- 34B	The second second	X						X				X											
35A		1						X				7											
*** 35 B		Y						1	and the Control		-	Υ.										,	-
000 364		X						χ				X											
010 36B	4	Х			M			X				χ.											
Relinquished By		Date	e / Tin	ne	<u></u>				ثحصد			Rece	ived E	ly			<u> </u>		Dat	e/Ti	me		
Devon (Zathbun)	10-24.2	ツえる						M	عاد	عالم	C	HIC	ll		uguyuyu mgazadir		115	Mi	m:	<u>></u>	10	<u>19</u>	
			n married in the later									والمستعدد والمستعدد	SOLUTION AND A SECURE	···							-		
			· · · · · · · · · · · · · · · · · · ·									Person transferred Clare		n me nomentilenon,					***************************************				
															<u></u>								

CHAIN OF CUSTODY

pg. 8 of 10 Work Order \$ 23101944

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005

Client: J. S. Hell			——					O Blue					-	C		
Address: 6 Meadow Heights 1	Prof Park			rebe	rved.	n. E	Lab	۵fi	ald:	FOR	LARI	use c	DINEY			
City State Zip: Collinsville, IL 622.	34			ab N	ojas,											
Contact: Jim Yasitis	Phone: 6/8-	343-3590														
E-Mail: james.yasitis@jsheld.com	Fax: <u>6/8-</u>	343-3597			ienis		Pu.	e Eie	enn 20		22) ₍ #				
PAre these samples known to be involved in litigation PAre these samples known to be hazardous? □ Yes PAre there any required reporting limits to be met on the limits in comment section. 图 Yes □ No	M No		se value					e 1-4 2pb.								
Project Name / Number	Sample Coll	ector's Name		M	ATRI	X		1	NDICA	TE AN	alysi.	s rec)UES	TED		
Wentzville SD Water Sampling B. 231000104	Brad Frisch					general december	()	State of the Association of the State of the		(VO)Limitement					1 P 1 P 1 P 1 P 1 P 1 P 1 P 1 P 1 P 1 P	
Results Requested Billing Standard 1-2 Day (100% Surcharge)		# and Type of C		900	AA G	9	(pm)		ACT PRODUCTION	a) month of the last		and the same of th				
□ Other □ 3 Day (50% Surcharge)		UNPRES MNO3 NAOH HISO4	MeOH NaHSO4 Other	Water	Unnking valer Soil	Studige So. Waste	~		ar of countries			- Annah di da	7			. }
Lab Use Only Sample Identification Date	/Time Sampled	T S S S S	Nec	Was I	Soil	Ser.	Lea					a Drymosodo				
		X .			(X									
Sept. 37B		X		1	()		X			·						
03 38A	· ·	XIII			X		X									
784 38B		χ			χĹ		χ									
15 39 A		X			χ		X									
C.L. 39 <i>B</i>		X			X		X									
GD 40A		χ			χ		7									
OF YOB		Y = 1			k]		X						-		<u>. </u>	
0,0 411		y			χ		X									
OD YIB	4	X			x		X									
Relinquished By		Date / Time		T			Rec	sived By					Date			
Devon (Zathbun	10-24-20	える		D	M	ا با	Jel	all	λ] [1	Opy	Ja3		210	<i>†</i>
						page and the second second second	- Colombia de la Colo	THE PERSON NAMED IN STREET		in language and the specific and the spe	_					- Lagranda
							nie zzarone zoer perch	Den Dog Tan Brock 1270		/				<u> </u>		
· · · · · · · · · · · · · · · · · · ·																

CHAIN OF CUSTODY

pg. <u>4</u> of <u>10</u> Work Order #.23101949

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005

Client: J. S. Held							5	ACTIVITY.	DII@S	5 (Q) () ₋ ₋		.03		RP JUGE		1,400 1	C/E							
Address: 6 Meadow Heights Prof,	Park						P	res	2FV.0	ect i	(0.	Ľ3 1	₌alb		Field:		FOI	RLA	<u>e</u> (18E	onl	Ý			
City State Zip: Collinsville, IL 62234								ab l	(ol	98;															
Contact: Jim Vasitis Phon	e: <u>618-3</u>	43-	3590)																					
E-Mail: james. yasitis@jsheld.com Fax:	618-3	43-	3597					200A				f,	y . ,	e E	e Zeen a			2	49	, F					
Are these samples known to be involved in litigation? If yes Are these samples known to be hazardous? Yes Are there any required reporting limits to be met on the required in comment section.		. •		•										с I- ppb											
Project Name / Number Sa	mple Colle	ctor'	s Nai	ne					MAT	r.	X				INDI	CAT	ear	IALY	SIS	RE	QUE	STE	D		
Wentzuille SD Water Sampling Brad	Frisch							and the second	lier.	and the party lives	CALCOCOMPANION AND AND AND AND AND AND AND AND AND AN		<u></u>	all control of the co	all property and a second	CONTRACTOR OF THE PARTY OF THE			-						
Results Requested Standard 1-2 Day (100% Surcharge)	11		Type			-	-		o We	and the same of th	, mariji da mira	93.	(DW)	-	Jac was a second	g- El porsoción		ena que do major do	r salakizani'ni sa	and Trooping				•	
□ Other □ □ 3 Day (50% Surcharge)	0 0	2 6	NaOH H2SO4		MeOH	NSO4	ie.	Water	Drinking Water	Soil	Sludge	Sp. Waste	ad		N-CASH CHARLES AND ASSESSED.	O. S. Confedence of the Confed	- Cita-glacycy areas dai	Sec. Characteristics		The state of the s	o Canada Dange and Andreas				
Lab Use Only Sample Identification Date/Time	Sampled		Na Na Na	2	Me	Z	5	AN .	à	Š	ā	S	Lea		Į.	-									
230 GA 42A 624433 E					\prod				X				X							Or Hand Company		O. Mary graffen, Mary			
(1) U2 B	1 7								χ̈́				X		A Procedural	"					<i></i>	tellerus almana.			
023 UBA	1 7	7							X				X									******			
C24 43B	X				\prod				χ				X									Standing of the Land			
125 44A · *] . [}								χ				X						•						
C26 44B									χ				X												
O27 45 A		r							X				7												
CM 45B									k				8												
024 46A		X							χ			·	X			-									
CS 46B	8	X							X				X						Company of the Compan						
Relinquished By		Date	/Tim	10	<u> </u>	اسبت	1=	T		<u> </u>	(<u></u>	1	Rec	ived E	Зу						Dat	e/T	ime		
Devon (Zathbun)	10-24.202	2 /							\mathcal{Y}	u	Q	1	Qi	لى	حا	<u> </u>	Over statement of the s		10	104	M:	<u> </u>	10	19	
	MATERIAL MATERIAL SERVICE STREET, STRE		- Particular	33- 		×20,000					www.Pad		-curve executive			***************************************	na di kanana di kan		la Con Horman Marie						
				-								-	Object Court of the Court of th	and the second of the second o	Commence was respected to the										
																<u>.</u>								***********	

CHAIN OF CUSTODY

pg. 10 of 10 Work Order \$23101949

TEKLAB, INC. 5445 Horseshoe Lake Road ~ Collinsville, IL 62234 ~ Phone: (618) 344-1004 ~ Fax: (618) 344-1005

Client: J. S. Held															1							40			
Address: 6 Meadow Heig	hts Profi	Park			***************************************				res	GLA(ed ír	L.	l	al0	o e	ield.	[OR I	.A8	USE:	oml	ľ.			
City State Zip: Collinsville, IL &	(2234	4. m 1. m.							ab.	Noi	95,														
Contact: Jim Vasitis	Phon	e: <u>618</u> -	343	35	90																				
E-Mail: james, yasitis@jsheld.co.	nFax:	618	343	359	77			100000	ženi (7)				p		, E.	2	n zav	i l	2.2	ŷ ₁ z					
 Are these samples known to be involved in liti Are these samples known to be hazardous? I Are there any required reporting limits to be m limits in comment section. 图 Yes □ No 	⊒Yes ⊠ No	o				•									ppb.										
Project Name / Number	Sai	mple Col	lecto	r's A	lamo) ·				MA"	TRI)	7				INDIC	ATE.	ANA	LYSI	s re	QUE	STE	D,		
Wentzuille SD Water Sampling 231000104	Brad	Frisch						,		iter.	and the second	BODDO-C-OD	-		-	The Company of the Co						Angles and Property States	and discontinuous was		
Results Requested Bi	lling Instru	ctions	# and					rs		3 We		Ş	١	(DW)		Contraction (Contraction)	Post of God					2		-	
☐ Other ☐ 3 Day (50% Surcharge)	•		UNPRES	2 I	ő		\$04	Other	Water	Drinking Water		Sin Waste	1	8			A POLICY TO A POLI					1	and the second second		,
Lab Use Only Sample Identification	Date/Time	Sampled	d No	NaO	Z28		MaN	Othe	Wa	Ö	Soil		2	Lea											
29019 47A	10-24-23 3	:00 AM	X	1.		1			-	X				X			/_								
OSL 47B			X							X.				X			.51								
			χ	1						X				K											
			X	1						χ				X											
V V			X							X				X					·						
			X		\prod		T			χ				X	-										
			X							X				7											
			Y							Th				8									<u>.</u>		
22.00			Ty.							X		·	·	K											
	1	4	X			T	İ			K				X								·			
Relinquished By	1		Dat	e/T	ime				<u>"T</u>	<u></u>	بالسبيط		F	lece	ved B	<u></u>					Dat	e/T	ime		
Devon (Zathbun		10-24.2	७३३					52.685.403.41.	I	V	MC	بر	I	Vil	Oll	2				NY	13		019	<u>}</u>	
		1 7 2 2 4 Table to the contract of the contrac			P. disease									MONTH PROPERTY.						, .		Table State of State of The Sta			p-4************************************
															terpetik og mennyetting klistere				<u> </u>						

23101948/23101949

TABLE 1

Drinking Water Sampling for Lead Content Wentzville R-IV School District **Discovery Ridge Elementary School** Sampled: October 24, 2023

Samp	le ID Location	Water Source	Results (ppb)
01A	Kitchen- Single Bay	Sink	
01B	Kitchen- Single Bay	Sink	
02A	Kitchen- Dishwashing Sprayer	Sink	
02B	Kitchen- Dishwashing Sprayer	Sink	
03A	Kitchen- 3 Bay (Left) Dishwashing Sprayer	Sink	
03B	Kitchen- 3 Bay (Left) Dishwashing Sprayer	Sink	
04A	Kitchen- 3 Bay (Right)	Sink	
04B	Kitchen- 3 Bay (Right)	Sink	
05A	Kitchen- 2 Bay	Sink	
05B	Kitchen- 2 Bay	Sink	
06A	Kitchen- Pot Filler	Sink	
06B	Kitchen- Pot Filler	Sink	
07	Kitchen- Ice Machine	Ice Machine	
08A	Near Room C4 (Left)	Fountain	
08B	Near Room C4 (Left)	Fountain	
09A	Near Room C4 (Left Center)	Fountain	
09B	Near Room C4 (Left Center)	Fountain	
10A	Near Room C4 (Right Center)	Fountain	
10B	Near Room C4 (Right Center)	Fountain	
11A	Near Room C4 (Right)	Fountain	
11B	Near Room C4 (Right)	Fountain	
12A	Room C11	Sink	
12B	Room C11	Sink	
13A	Room C10	Sink	
13B	Room C10	Sink	
14A	Room C12	Sink	
14B	Room C12	Sink	
15A	Room C13	Sink	
15B	Room C13	Sink	
16A	Near Room C12 (Left)	Fountain	
16B	Near Room C12 (Left)	Fountain	
17A	Near Room C12 (Right)	Fountain	
17B	Near Room C12 (Right)	Fountain	
18A	Near Room C11 (Left)	Fountain	
18B	Near Room C11 (Left)	Fountain	

Samp	TE ID LOCATION	Water Source	rcsuits (ppb)
19A	Near Room C11 (Right)	Fountain	
19B	Near Room C11 (Right)	Fountain	
20A	Near Room C26 (Left)	Fountain	
20B	Near Room C26 (Left)	Fountain	
21A	Near Room C26 (Left Center)	Fountain	
21B	Near Room C26 (Left Center)	Fountain	
22A	Near Room C26 (Right Center)	Fountain	
22B	Near Room C26 (Right Center)	Fountain	
23A	Near Room C26 (Right)	Fountain	
23B	Near Room C26 (Right)	Fountain	
23B 24A	Near Room C2 (Left)	Fountain	
24A 24B	Near Room C2 (Left)	Fountain	
24B 25A	Near Room C2 (Left Center)	Fountain	
25A 25B	Near Room C2 (Left Center)	Fountain	
25B 26A	Near Room C2 (Right Center)	Fountain	
26B	Near Room C2 (Right Center)	Fountain	
20B 27A	Near Room C2 (Right)	Fountain	
27B	Near Room C2 (Right)	Fountain	
27B 28A	Room A5 Teacher's Lounge	Sink	
28B	Room A5 Teacher's Lounge	Sink	
28B 29	Room A5 Teacher's Lounge	Ice Machine	
30A	Room A6 Nurses Office	Sink	
30B	Room A6 Nurses Office	Sink	
31A	Near Room E1 (Left)	Fountain	
31B	Near Room E1 (Left)	Fountain	
32A	Near Room E1 (Left Center)	Fountain	
32B	Near Room E1 (Left Center)	Fountain	
33A	Near Room E1 (Right Center)	Fountain	
33B	Near Room E1 (Right Center)	Fountain	
34A	Near Room E1 (Right)	Fountain	
34B	Near Room E1 (Right)	Fountain	1,
35A	Near Room D2 (Left)	Fountain	9
35B	Near Room D2 (Left)	Fountain	\subseteq
36A	Near Room D2 (Left Center)	Fountain	
36B	Near Room D2 (Left Center)	Fountain	
37A	Near Room D2 (Right Center)	Fountain	0
37B	Near Room D2 (Right Center)	Fountain	
38A	Room DB2	Sink	,
38B	Room DB2	Sink	į
39A	Near Room D2 (Right)	Fountain	-
39B	Near Room D2 (Right)	Fountain	•
40A	Near Room E3 (Left)	Fountain	•
40B	Near Room E3 (Left)	Fountain	•
	Near Room E3 (Left Center)	Fountain	
41A	Near Room Es (Len Center)	1 Ountain	

Water Source

Results (ppb)

Sample ID Location

Samp	ole ID Location	Water Source	Results (ppb)
42A	Near Room E3 (Right Center)	Fountain	
42B	Near Room E3 (Right Center)	Fountain	
43A	Near Room E3 (Right)	Fountain	
43B	Near Room E3 (Right)	Fountain	
44A	Near Room F21A (Left)	Fountain	
44B	Near Room F21A (Left)	Fountain	
45A	Near Room F21A (Left Center)	Fountain	
45B	Near Room F21A (Left Center)	Fountain	
46A	Near Room F21A (Right Center)	Fountain	
46B	Near Room F21A (Right Center)	Fountain	
47A	Near Room F21A (Right)	Fountain	
47B	Near Room F21A (Right)	Fountain	



Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.

#####

Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum

Sample Legend

"A" = First Draw

"B" = Second Draw

APPENDIX C CREDENTIALS

STATE OF MISSOURI DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Bradley M. Frisch

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date:

3/1/2022

Expiration Date:

3/1/2024

License Number:

160229-300004900



Paula F. Nickelson

Acting Director

Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

PUBLIC HEALTH & SOCIAL JUSTICE

SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

Brad Frisch

2668 Kettering Court, Saint Charles, MO 63303

contact hours of training and successfully passed an examination ∞ has attended

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 - 3/7/2022 - 117395

Christopher C. Kinc

Director, Center for Environmental Education and Training

Examination Date: 3/7/2022

CEUs: 0.8

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104 (314) 977-8256 slu.edu/x39753.xml This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

State of Missouri Department of Natural Resources

Certificate of Approval for Chemical Laboratory Service

This is to certify that

Teklab, Incorporated

is hereby approved to perform the analysis of drinking water as specified on the Certified Parameter List, which must accompany this certificate to be valid.

Certification Number	930	Godflood
Date Issued	December 13, 2021	Laboratory Ced frication Authority, Public Drinking Water Branch Missouri Department of Natural Resources
Expiration Date	January 31, 2025	Rola Visel
		Laboratory Certification Officer, Environmental Services Program

STATE OF ILLINOIS

ENVIRONMENTAL PROTECTION AGENCY NELAP - RECOGNIZED

ENVIRONMENTAL LABORATORY ACCREDITATION

is hereby granted to

Teklab, Incorporated 5445 Horseshoe Lake Rd. Collinsville, IL 62234 **NELAP ACCREDITED**

Accreditation Number #100226



According to the Illinois Administrative Code, Title 35, Subtitle A, Chapter II, Part 186, ACCREDITATION OF LABORATORIES FOR DRINKING WATER, WASTEWATER AND HAZARDOUS WASTES ANALYSIS, the State of Illinois formally recognizes that this laboratory is technically competent to perform the environmental analyses listed on the scope of accreditation detailed below.

The laboratory agrees to perform all analyses listed on this scope of accreditation according to the Part 186 requirements and acknowledges that continued accreditation is dependent on successful ongoing compliance with the applicable requirements of Part 186. Please contact the Illinois EPA Environmental Laboratory Accreditation Program (IL ELAP) to verify the laboratory's scope of accreditation and accreditation status. Accreditation by the State of Illinois is not an endorsement or a guarantee of validity of the data generated by the laboratory.

Primary Accrediting Authority: Illinois

Millie Rose Supervisor

Environmental Laboratory Accreditation Program

Certificate No: 1002262023-17

Expiration Date: 1/31/2024 Issued On: 4/11/2023

MillicRose

State of Illinois

Environmental Protection Agency

Awards the Certificate of Approval to:

Teklab, Incorporated 5445 Horseshoe Lake Rd. Collinsville, IL 62234

The Illinois Environmental Laboratory Accreditation Program encourages all clients and data users to verify the most current scope of accreditation for Teklab, Incorporated.

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Method EPA 120.1	п
Conductivity	IL
Method EPA 1631E	
Mercury	IL
Method EPA 1664A Rev: 1	
Oil & Grease	IL
Method EPA 180.1 Rev: 2	
Turbidity	IL
Method EPA 200.7 Rev: 4.4	
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Magnesium	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL :
Sodium	IL II
Thallium	IL II
Tin Titanium	IL IL
Vanadium	IL IL
Zinc	IL
	IL
Method EPA 200.8 Rev: 5.4	
Aluminum	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Cadmium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Lead	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Selenium	IL
Silver	IL
Thallium	IL
Vanadium	IL
Zinc	IL
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 335.4 Rev: 1	
Cyanide	IL
Method EPA 350.1 Rev: 2	
Ammonia as N	IL
	12
Method EPA 351.2 Rev: 2	
Total Kjeldahl Nitrogen (TKN)	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Nitrite as N	IL
Method EPA 365.4	
Phosphorus	IL
Method EPA 375.2 Rev: 2	
Sulfate	IL
Method EPA 410.4 Rev: 2	
Chemical oxygen demand	IL
	12
Method EPA 420.1	п
Total phenolics	IL
Method EPA 420.4 Rev: 1	
Total phenolics	IL
Method EPA 608.3 GC-ECD	
4,4'-DDD	IL
4,4'-DDE	IL
4,4'-DDT	IL
Aldrin	IL
alpha-BHC (alpha-Hexachlorocyclohexane)	IL
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Araclar-1242 (PCB-1242)	II

IL

Aroclor-1242 (PCB-1242)

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Non Potable Water) Aroclor-1248 (PCB-1248) IL Aroclor-1254 (PCB-1254) IL Aroclor-1260 (PCB-1260) IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL IL Endosulfan I Endosulfan II IL Endosulfan sulfate IL Endrin IL Endrin aldehyde IL gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL Heptachlor IL Heptachlor epoxide IL Methoxychlor IL IL Toxaphene (Chlorinated camphene) Method EPA 615 2,4,5-T IL 2,4-D IL Dicamba IL Silvex (2,4,5-TP) IL Method EPA 624.1 1,1,1-Trichloroethane IL 1,1,2,2-Tetrachloroethane IL 1,1,2-Trichloroethane IL 1,1-Dichloroethane IL 1,1-Dichloroethylene IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,2-Dichloroethane (Ethylene dichloride) IL 1,2-Dichloropropane IL 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL 2-Chloroethyl vinyl ether IL Acetonitrile IL Acrolein (Propenal) IL Acrylonitrile IL Benzene IL Bromodichloromethane IL IL Bromoform IL Carbon tetrachloride Chlorobenzene IL Chlorodibromomethane IL Chloroethane (Ethyl chloride) IL Chloroform IL cis-1,3-Dichloropropene IL Ethylbenzene IL Methyl bromide (Bromomethane) IL Methyl chloride (Chloromethane) IL Methyl tert-butyl ether (MTBE) IL Methylene chloride (Dichloromethane) IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Non Potable Water) Tetrachloroethylene (Perchloroethylene) IL Toluene IL trans-1,2-Dichloroethylene IL trans-1,3-Dichloropropylene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL IL Vinyl chloride IL Xylene (total) Method EPA 625.1 1,2,4-Trichlorobenzene IL 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,6-Trichlorophenol IL IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL 2-Nitrophenol IL 3,3'-Dichlorobenzidine IL IL 4-Bromophenyl phenyl ether IL 4-Chloro-3-methylphenol 4-Chlorophenyl phenylether IL 4-Nitrophenol IL Acenaphthene IL Acenaphthylene IL Anthracene IL Benzidine IL Benzo(a)anthracene IL Benzo(a)pyrene IL Benzo(b)fluoranthene IL IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chrysene IL IL Dibenz(a,h) anthracene Diethyl phthalate IL Dimethyl phthalate IL IL Di-n-butyl phthalate Di-n-octyl phthalate IL Fluoranthene ILFluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL IL Hexachlorocyclopentadiene Hexachloroethane IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water)	
Indeno(1,2,3-cd) pyrene	IL
Isophorone	IL
Naphthalene	IL
Nitrobenzene	IL
n-Nitrosodimethylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
Pentachlorophenol Phenanthrene	IL IL
Phenol	IL IL
Pyrene	IL
Pyridine	IL
Method OIA 1677-09	
Available Cyanide	IL
Method SM 2120 B-2011	
Color	IL
Method SM 2130 B-2011	, <u> </u>
Turbidity	IL
•	IL.
Method SM 2310 B-2011	IL
Acidity, as CaCO3	IL
Method SM 2320 B-2011	
Alkalinity as CaCO3	IL
Method SM 2340 B-1997	
Hardness	IL
Method SM 2510 B-2011	
Conductivity	IL
Method SM 2540 B-2011	
Residue-total	IL
Method SM 2540 C-2011	
Residue-filterable (TDS)	IL
Method SM 2540 D-2011	
Residue-nonfilterable (TSS)	IL
Method SM 2540 E-2011	
Residue-volatile	IL
Method SM 2540 F-2011	
Residue-settleable	IL
Method SM 3500-Cr B-2011	
Chromium VI	IL
Method SM 4500-CI G-2011	
Total residual chlorine	IL
Method SM 4500-CI C-1997	
Chloride	IL
Method SM 4500-Cl C-2011	
Chloride	IL
Method SM 4500-Cl E-2000	· -
Chloride	IL
	12
Method SM 4500-CI E-2011	

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Non Potable Water) Chloride	IL
Method SM 4500-F C-2011 Fluoride	IL
Method SM 4500-H+ B-2011 pH	IL
Method SM 4500-NH3 G-2011 Ammonia	IL
Method SM 4500-NO2 B-2011 Nitrite	IL
Method SM 4500-NO3 F-2000 Nitrate plus Nitrite as N	IL
Method SM 4500-O G-2001 Oxygen, dissolved	IL
Method SM 4500-P E-2011 Orthophosphate as P	IL
Method SM 4500-S2 D-2011 Sulfide	IL
Method SM 4500-SO3 B-2011 Sulfite-SO3	IL
Method SM 5210 B-2011 Biochemical oxygen demand Carbonaceous BOD, CBOD	IL IL
Method SM 5220 D-2011 Chemical oxygen demand	IL
Method SM 5310 C-2011 Total organic carbon	IL
Method SM 5540 C-2011 Surfactants - MBAS	IL

Field of Testing /Matrix: CWA (Solid & Hazardous Material)	
Method EPA 160.4	
Residue-volatile	IL
	·-
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 351.2 Rev: 2	
Total Kjeldahl Nitrogen (TKN)	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Nitrite as N	IL
Method EPA 365.4	
Phosphorus	IL
Method EPA 420.1	
Total phenolics	IL
Method EPA 608.3 GC-ECD	
4,4'-DDD	IL
4,4'-DDE	IL IL
4,4'-DDT	IL
Aldrin	IL
alpha-BHC (alpha-Hexachlorocyclohexane)	IL
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Aroclor-1242 (PCB-1242)	IL
Aroclor-1248 (PCB-1248)	IL
Aroclor-1254 (PCB-1254)	IL
Aroclor-1260 (PCB-1260)	IL
beta-BHC (beta-Hexachlorocyclohexane)	IL
Chlordane (tech.)(N.O.S.)	IL
delta-BHC	IL
Dieldrin	IL
Endosulfan I	IL
Endosulfan II	IL
Endosulfan sulfate	IL
Endrin	IL
Endrin aldehyde	IL
gamma-BHC (Lindane, gamma-Hexachlorocyclohexane)	IL
Heptachlor	IL
Heptachlor epoxide	IL
Methoxychlor	IL
Toxaphene (Chlorinated camphene)	IL
Method EPA 624.1	
1,1,1-Trichloroethane	IL
1,1,2,2-Tetrachloroethane	IL
1,1,2-Trichloroethane	IL
1,1-Dichloroethane	IL
1,1-Dichloroethylene	IL
1,2-Dichlorobenzene (o-Dichlorobenzene)	IL
1,2-Dichloroethane (Ethylene dichloride)	IL
1,2-Dichloropropane	IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: CWA (Solid & Hazardous Material) 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL 2-Chloroethyl vinyl ether IL Acetonitrile IL Acrolein (Propenal) IL IL Acrylonitrile Benzene IL Bromodichloromethane IL Bromoform IL Carbon tetrachloride IL Chlorobenzene IL Chlorodibromomethane IL Chloroethane (Ethyl chloride) IL Chloroform IL IL cis-1,3-Dichloropropene IL Ethylbenzene Methyl bromide (Bromomethane) IL Methyl chloride (Chloromethane) IL Methyl tert-butyl ether (MTBE) IL Methylene chloride (Dichloromethane) IL Tetrachloroethylene (Perchloroethylene) IL Toluene IL IL trans-1,2-Dichloroethylene trans-1,3-Dichloropropylene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL Vinyl chloride IL Xylene (total) IL Method EPA 625.1 1,2,4-Trichlorobenzene IL 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,6-Trichlorophenol IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol IL 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL 2-Nitrophenol IL IL 3,3'-Dichlorobenzidine 4-Bromophenyl phenyl ether IL 4-Chloro-3-methylphenol IL 4-Nitrophenol IL Acenaphthene IL Acenaphthylene IL Anthracene IL Benzidine IL Benzo(a)anthracene IL IL Benzo(a)pyrene Benzo(b)fluoranthene IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: CWA (Solid & Hazardous Material)	
Benzo(g,h,i)perylene	IL
Benzo(k)fluoranthene	IL
bis(2-Chloroethoxy)methane	IL
bis(2-Chloroethyl) ether	IL
bis(2-Ethylhexyl) phthalate (DEHP)	IL
Butyl benzyl phthalate	IL
Carbazole	IL
Chrysene	IL
Dibenz(a,h) anthracene	IL
Diethyl phthalate	IL
Dimethyl phthalate	IL
Di-n-butyl phthalate	IL
Di-n-octyl phthalate	IL
Fluoranthene	IL
Fluorene	IL
Hexachlorobenzene	IL
Hexachlorobutadiene	IL
Hexachlorocyclopentadiene	IL
Hexachloroethane	IL
Indeno(1,2,3-cd) pyrene	IL
Isophorone	IL
Naphthalene	IL
Nitrobenzene	IL
n-Nitrosodimethylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
Pentachlorophenol	IL
Phenanthrene Phenol	IL
	IL
Pyrene	IL
Pyridine	IL
Method SM 2340 B-1997	
Hardness	IL
Method SM 2540 C-1997	
Residue-filterable (TDS)	IL
Method SM 2540 F-1997	
Residue-settleable	IL
Method SM 4500-CI C-1997	
Chloride	IL
Method SM 4500-Cl C-2011	16
	11
Chloride	IL
Method SM 4500-CI E-2000	
Chloride	IL
Method SM 4500-NO2 B-2011	
Nitrite	IL
Method SM 4500-NO3 F-2000	
Nitrate plus Nitrite as N	IL
Method SM 4500-P E-1999	
Orthophosphate as P	IL
Οι πορποσμιαί ο ασ τ	IL.

Certificate No.: 1002262023-17 Primary AB

Field of Testing /Matrix: CWA (Solid & Hazardous Material)

Method SM 4500-SO3 B-2000

Sulfite-SO3

Certificate No.: 1002262023-17 Primary AB

Certificate No.: 1002262023-17	· · · · · · · · · · · · · · · · · · ·
Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 1010A	
Ignitability	IL
Method EPA 1020B	
Ignitability	IL
Method EPA 1311 Rev: 0	
Toxicity Characteristic Leaching Procedure (TCLP)	IL
Method EPA 1312 Rev: 0	
Synthetic Precipitation Leaching Procedure (SPLP)	IL
Method EPA 6010B Rev: 2	"L
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	iL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Lithium	IL
Magnesium	IL
Manganese	IL IL
Molybdenum Nickel	IL IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL
Sodium	IL
Strontium	IL
Thallium	IL
Tin	IL
Titanium	IL
Vanadium	IL
Zinc	IL
Method EPA 6020A Rev: 1	
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium Bondlium	IL II
Beryllium Boron	IL IL
Boron Cadmium	IL IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
••	

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: RCRA (Non Potable Water) Iron IL Lead IL Magnesium IL Manganese IL Molybdenum IL Nickel IL Potassium IL Selenium IL Silver IL Sodium IL **Thallium** IL Vanadium IL IL Zinc Method EPA 7196A Rev: 1 Chromium VI IL Method EPA 7470A Rev: 1 Mercury IL Method EPA 8015B Rev: 2 IL Diesel range organics (DRO) Ethanol IL Ethylene glycol IL Isobutyl alcohol (2-Methyl-1-propanol) IL Isopropyl alcohol (2-Propanol, Isopropanol) IL IL Methanol n-Butyl alcohol (1-Butanol, n-Butanol) IL n-Propanol (1-Propanol) IL IL tert-Butyl alcohol Method EPA 8081B 4,4'-DDD IL 4,4'-DDE IL 4,4'-DDT IL Alachlor IL Aldrin IL IL alpha-BHC (alpha-Hexachlorocyclohexane) alpha-Chlordane, cis-Chlordane IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL Endosulfan I IL Endosulfan II IL Endosulfan sulfate IL **Endrin** IL Endrin aldehyde IL Endrin ketone IL gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL gamma-Chlordane IL Heptachlor IL Heptachlor epoxide IL Methoxychlor IL Toxaphene (Chlorinated camphene) IL

Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 8082 Rev: 0	
Aroclor-1016 (PCB-1016)	IL
Aroclor-1221 (PCB-1221)	IL
Aroclor-1232 (PCB-1232)	IL
Aroclor-1242 (PCB-1242)	IL
Aroclor-1248 (PCB-1248)	IL
Aroclor-1254 (PCB-1254)	IL
Aroclor-1260 (PCB-1260)	IL
Method EPA 8151A	
2,4,5-T	IL
2,4-D	IL
2,4-DB	IL
3,5-Dichlorobenzoic acid	IL
4-Nitrophenol	IL
Acifluorfen	IL
Bentazon	IL
Chloramben	IL
Dalapon	IL
DCPA di acid degradate	IL
Dicamba	IL
Dichloroprop (Dichlorprop)	IL
Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP)	IL
MCPA	IL IL
MCPP	IL "
Pentachlorophenol	IL "
Picloram	IL
Silvex (2,4,5-TP)	IL
Method EPA 8260B	
1,1,1,2-Tetrachloroethane	IL
1,1,1-Trichloroethane	IL
1,1,2,2-Tetrachloroethane	IL
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	IL
1,1,2-Trichloroethane	IL
1,1-Dichloroethane	IL
1,1-Dichloroethylene	IL
1,1-Dichloropropene	IL
1,2,3-Trichlorobenzene	IL
1,2,3-Trichloropropane	IL
1,2,4-Trichlorobenzene	IL
1,2,4-Trimethylbenzene	IL
1,2-Dibromo-3-chloropropane (DBCP)	IL
1,2-Dibromoethane (EDB, Ethylene dibromide)	IL
1,2-Dichlorobenzene (o-Dichlorobenzene)	IL
1,2-Dichloroethane (Ethylene dichloride)	IL
1,2-Dichloropropane	IL
1,3,5-Trimethylbenzene	IL
1,3-Dichlorobenzene	IL
1,3-Dichloropropane	IL
1,4-Dichlorobenzene	IL
1-Chlorobutane	IL
2,2-Dichloropropane	IL

ld of Testing /Matrix: RCRA (Non Potable Water)	
2-Butanone (Methyl ethyl ketone, MEK)	IL
2-Chloroethyl vinyl ether	IL
2-Chlorotoluene	iL
2-Hexanone	iL
2-Nitropropane	IL
4-Chlorotoluene	IL
4-Isopropyltoluene (p-Cymene,p-Isopropyltoluene)	IL
4-Methyl-2-pentanone (MIBK)	IL
Acetone	IL
Acetonitrile	IL
Acrolein (Propenal)	IL
Acrylonitrile	IL
Allyl chloride (3-Chloropropene)	IL
Benzene	IL
Bromobenzene	IL
Bromochloromethane	ïL
Bromodichloromethane	ĪL
Bromoform	iL
Carbon disulfide	IL
Carbon tetrachloride	IL
Chlorobenzene	IL
Chlorodibromomethane	IL.
Chloroethane (Ethyl chloride)	IL
Chloroform	IL
Chloroprene (2-Chloro-1,3-butadiene)	IL
cis-1,2-Dichloroethylene	IL
cis-1,3-Dichloropropene	iL
cis-1,4-Dichloro-2-butene	IL
Dibromomethane (Methylene bromide)	IL
Dichlorodifluoromethane (Freon-12)	IL
Diethyl ether	IL
Di-isopropylether (DIPE) (Isopropyl Ether)	IL
Ethyl acetate	IL
Ethyl methacrylate	IL
Ethylbenzene	IL
Hexachlorobutadiene	IL
Hexachloroethane	IL
Iodomethane (Methyl iodide)	IL
Isopropylbenzene	IL
m+p-xylene	IL
Methacrylonitrile	IL
Methyl acrylate	IL
Methyl bromide (Bromomethane)	IL
Methyl chloride (Chloromethane)	IL
Methyl methacrylate	IL
Methyl tert-butyl ether (MTBE)	IL
Methylene chloride (Dichloromethane)	IL
m-Xylene	IL
Naphthalene	IL
n-Butylbenzene	IL
Nitrobenzene	IL
n-Propylbenzene	iL

Certificate No.: 1002262023-17 Primary AB

Certificate 140 1002202011	
Field of Testing /Matrix: RCRA (Non Potable Water)	
o-Xylene	IL
Pentachloroethane	IL
Propionitrile (Ethyl cyanide)	IL
p-Xylene	IL
sec-Butylbenzene	IL
Styrene	IL
tert-Butyl alcohol	IL
tert-Butylbenzene	IL
Tetrachloroethylene (Perchloroethylene)	IL
Tetrahydrofuran (THF)	IL
Toluene	IL
trans-1,2-Dichloroethylene	IL
trans-1,3-Dichloropropylene	IL
	IL
Trichloroethene (Trichloroethylene)	IL
Trichlorofluoromethane (Fluorotrichloromethane, Freon 11)	IL
	IL
·	IL
·	IL
Method EPA 8270C Rev: 3	
	IL
	IL
·	IL
	IL
	IL
	IL
·	IL
·	IL IL
	IL
·	IL IL
	IL
	IL IL
·	IL IL
	IL IL
· · · · · · · · · · · · · · · · · · ·	IL IL
•	IL IL
·	IL IL
·	IL IL
	IL IL
	IL
'	IL
•	IL
	IL
,	IL
	IL
	IL
•	IL
	IL
, ·	IL
4-Chloroaniline	IL

Primary AB Certificate No.: 1002262023-17 RCRA (Non Potable Water) Field of Testing /Matrix: 4-Chlorophenyl phenylether IL 4-Dimethyl aminoazobenzene IL 4-Methylphenol (p-Cresol) IL 4-Nitroaniline IL 4-Nitrophenol IL 5-Nitro-o-toluidine IL IL 7,12-Dimethylbenz(a) anthracene IL Acenaphthene Acenaphthylene IL IL Acetophenone Aniline IL Anthracene IL Benzidine IL Benzo(a)anthracene IL IL Benzo(a)pyrene Benzo(b)fluoranthene IL IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene Benzoic acid IL Benzyl alcohol IL bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chlorobenzilate IL Chrysene IL IL Diallate Dibenz(a,h) anthracene IL Dibenzofuran IL Diethyl phthalate IL IL Dimethoate IL Dimethyl phthalate Di-n-butyl phthalate IL Di-n-octyl phthalate IL Diphenylamine IL Ethyl methanesulfonate IL **Famphur** IL Fluoranthene IL Fluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL Hexachlorocyclopentadiene IL Hexachloroethane IL Hexachloropropene IL Indeno(1,2,3-cd) pyrene IL Isodrin IL Isophorone IL Isosafrole IL Methyl methanesulfonate IL Naphthalene IL

Nitrobenzene

IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Non Potable Water)	
n-Nitrosodiethylamine	IL
n-Nitrosodimethylamine	IL
n-Nitroso-di-n-butylamine	IL
n-Nitrosodi-n-propylamine	IL
n-Nitrosodiphenylamine	IL
n-Nitrosomethylethylamine	IL
n-Nitrosopiperidine	IL
n-Nitrosopyrrolidine	IL
o,o,o-Triethyl phosphorothioate	IL
Parathion	IL
Pentachlorobenzene	IL
Pentachloronitrobenzene	IL
Pentachlorophenol	IL
Phenanthrene	IL
Phenol	IL
Pronamide (Kerb)	IL
Pyrene	IL
Pyridine	IL
Safrole	IL
Method EPA 8270C Mod LVI	
Acetochlor	IL
Alachlor	IL
Atrazine	IL
Butylate	IL
Cyanazine	IL
EPTC (Eptam, s-ethyl-dipropyl thio carbamate)	IL
Metolachlor	IL
Metribuzin	IL
Pendimethalin (Penoxalin)	IL
Simazine	IL
Trifluralin (Treflan)	IL
Method EPA 9012A Rev: 1	
Cyanide	IL
Method EPA 9014 Rev: 0	
Cyanide	IL
Method EPA 9020B Rev: 2	
Total organic halides (TOX)	IL
	IL.
Method EPA 9023 Rev: 0	
Extractable organics halides (EOX)	IL
Method EPA 9036 Rev: 0	
Sulfate	IL
Method EPA 9040B Rev: 2	
pH	IL
Method EPA 9050A Rev: 1	
Conductivity	IL
Method EPA 9060A	
	п
Total organic carbon	IL
Method EPA 9065 Rev: 0	
Total phenolics	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Non Potable Water)	
Method EPA 9066 Rev: 0 Total phenolics	IL
Method EPA 9095A Paint Filter Test	IL
Method EPA 9214 Rev: 0 Fluoride	IL
Method EPA 9251 Rev: 0 Chloride	IL

Certificate No.: 1002262023-17

Certificate No.: 1002262023-17	
Field of Testing /Matrix: RCRA (Solid & Hazardous Material)	
Method EPA 1010A	
Ignitability	IL
Method EPA 1020B	
Ignitability	IL
Method EPA 1311 Rev: 0	
Toxicity Characteristic Leaching Procedure (TCLP)	IL
Method EPA 1312 Rev: 0	
Synthetic Precipitation Leaching Procedure (SPLP)	IL
Method EPA 6010B Rev: 2	ı <u>L</u>
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Boron	IL
Cadmium	IL
Calcium	IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL
Lead	IL
Lithium	IL
Magnesium	IL "
Manganese	IL IL
Molybdenum Nickel	IL IL
Phosphorus	IL
Potassium	IL
Selenium	IL
Silver	IL
Sodium	IL
Strontium	IL
Thallium	IL
Tin	IL
Titanium	IL
Vanadium	IL
Zinc	IL
Method EPA 6020A Rev: 1	
Aluminum	IL
Antimony	IL
Arsenic	IL
Barium Bondium	IL II
Beryllium	IL IL
Boron Cadmium	IL IL
Chromium	IL
Cobalt	IL
Copper	IL
Iron	IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Lead IL Magnesium IL IL Manganese Molybdenum IL Nickel IL IL Potassium Selenium IL Silver IL Sodium IL **Thallium** IL Vanadium IL Zinc IL Method EPA 7196A Rev: 1 IL Chromium VI Method EPA 7471B Mercury IL Method EPA 8015B Rev: 2 Diesel range organics (DRO) IL IL Ethanol Ethylene glycol IL Isobutyl alcohol (2-Methyl-1-propanol) IL Isopropyl alcohol (2-Propanol, Isopropanol) IL Methanol IL IL n-Butyl alcohol (1-Butanol, n-Butanol) n-Propanol (1-Propanol) IL tert-Butyl alcohol IL Method EPA 8081B 4,4'-DDD IL 4,4'-DDE IL 4,4'-DDT IL Alachlor IL Aldrin IL alpha-BHC (alpha-Hexachlorocyclohexane) IL alpha-Chlordane, cis-Chlordane IL beta-BHC (beta-Hexachlorocyclohexane) IL Chlordane (tech.)(N.O.S.) IL delta-BHC IL Dieldrin IL Endosulfan I IL Endosulfan II IL Endosulfan sulfate IL Endrin IL IL Endrin aldehyde IL Endrin ketone gamma-BHC (Lindane, gamma-Hexachlorocyclohexane) IL gamma-Chlordane IL Heptachlor IL Heptachlor epoxide IL IL Methoxychlor Toxaphene (Chlorinated camphene) IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Aroclor-1016 (PCB-1016) IL Aroclor-1221 (PCB-1221) IL Aroclor-1232 (PCB-1232) IL Aroclor-1242 (PCB-1242) IL Aroclor-1248 (PCB-1248) IL Aroclor-1254 (PCB-1254) IL Aroclor-1260 (PCB-1260) IL Method EPA 8151A 2.4.5-T IL 2,4-D IL 2,4-DB IL 3,5-Dichlorobenzoic acid IL IL 4-Nitrophenol IL Acifluorfen IL Bentazon Chloramben IL Dalapon IL DCPA di acid degradate IL Dicamba IL Dichloroprop (Dichlorprop) IL Dinoseb (2-sec-butyl-4,6-dinitrophenol, DNBP) IL **MCPA** IL **MCPP** IL IL Pentachlorophenol Picloram IL Silvex (2,4,5-TP) IL Method EPA 8260B 1,1,1,2-Tetrachloroethane IL IL 1,1,1-Trichloroethane IL 1,1,2,2-Tetrachloroethane 1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113) IL 1,1,2-Trichloroethane IL 1,1-Dichloroethane IL 1,1-Dichloroethylene IL 1,1-Dichloropropene IL IL 1,2,3-Trichlorobenzene 1,2,3-Trichloropropane IL 1,2,4-Trichlorobenzene IL IL 1,2,4-Trimethylbenzene 1,2-Dibromo-3-chloropropane (DBCP) IL 1,2-Dibromoethane (EDB, Ethylene dibromide) IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,2-Dichloroethane (Ethylene dichloride) IL 1,2-Dichloropropane IL 1,3,5-Trimethylbenzene IL IL 1,3-Dichlorobenzene 1,3-Dichloropropane IL 1,4-Dichlorobenzene IL 1-Chlorobutane IL 2,2-Dichloropropane IL 2-Butanone (Methyl ethyl ketone, MEK) IL

Certificate No.: 1002262023-17 Primary AB

ld of Testing /Matrix: RCRA (Solid & Hazardous Material)	
2-Chloroethyl vinyl ether	IL
2-Chlorotoluene	IL
2-Hexanone	IL
2-Nitropropane	iL
4-Chlorotoluene	IL
4-Isopropyltoluene (p-Cymene,p-Isopropyltoluene)	IL
4-Methyl-2-pentanone (MIBK)	IL
Acetone	IL
Acetonitrile	IL
Acrolein (Propenal)	IL
Allyl chloride (3-Chloropropene)	IL
Benzene	ı. IL
Bromobenzene	ı. IL
Bromochloromethane	IL
Bromodichloromethane	IL
Bromoform	IL
Carbon disulfide	IL
Carbon tetrachloride	IL
Chlorobenzene	
	IL "
Chlorodibromomethane	IL "
Chloroethane (Ethyl chloride)	IL "
Chloroform (2.01	IL "
Chloroprene (2-Chloro-1,3-butadiene)	IL
cis-1,2-Dichloroethylene	IL
cis-1,3-Dichloropropene	IL
cis-1,4-Dichloro-2-butene	IL
Dibromomethane (Methylene bromide)	IL
Dichlorodifluoromethane (Freon-12)	IL
Diethyl ether	IL
Di-isopropylether (DIPE) (Isopropyl Ether)	IL
Ethyl acetate	IL
Ethyl methacrylate	IL
Ethylbenzene	IL
Hexachlorobutadiene	IL
Hexachloroethane	IL
Iodomethane (Methyl iodide)	IL
Isopropylbenzene	IL
m+p-xylene	IL
Methacrylonitrile	IL
Methyl acrylate	IL
Methyl bromide (Bromomethane)	IL
Methyl chloride (Chloromethane)	IL
Methyl methacrylate	IL
Methyl tert-butyl ether (MTBE)	IL
Methylene chloride (Dichloromethane)	IL
m-Xylene	IL
Naphthalene	IL
n-Butylbenzene	IL
Nitrobenzene	IL
n-Propylbenzene	IL
o-Xylene	IL
Pentachloroethane	IL

Primary AB Certificate No.: 1002262023-17 RCRA (Solid & Hazardous Material) Field of Testing /Matrix: Propionitrile (Ethyl cyanide) IL p-Xylene IL sec-Butylbenzene IL Styrene IL tert-Butyl alcohol IL tert-Butylbenzene IL IL Tetrachloroethylene (Perchloroethylene) IL Tetrahydrofuran (THF) Toluene IL trans-1,2-Dichloroethylene IL trans-1,3-Dichloropropylene IL trans-1,4-Dichloro-2-butene IL Trichloroethene (Trichloroethylene) IL Trichlorofluoromethane (Fluorotrichloromethane, Freon 11) IL Vinyl acetate IL Vinyl chloride IL IL Xylene (total) Method EPA 8270C Rev: 3 1,2,4-Trichlorobenzene IL 1,2-Dichlorobenzene (o-Dichlorobenzene) IL 1,3-Dichlorobenzene IL 1,4-Dichlorobenzene IL IL 1,4-Dioxane (1,4- Diethyleneoxide) 2,2'-Oxybis(1-chloropropane), bis(2-Chloro-1-methylethyl)ether IL 2,4,5-Trichlorophenol IL 2,4,6-Trichlorophenol IL 2,4-Dichlorophenol IL 2,4-Dimethylphenol IL 2,4-Dinitrophenol IL 2,4-Dinitrotoluene (2,4-DNT) IL 2,6-Dinitrotoluene (2,6-DNT) IL 2-Chloronaphthalene IL 2-Chlorophenol IL 2-Methyl-4,6-dinitrophenol (4,6-Dinitro-2-methylphenol) IL IL 2-Methylaniline (o-Toluidine) 2-Methylnaphthalene IL 2-Methylphenol (o-Cresol) IL 2-Nitroaniline IL 2-Nitrophenol IL 3,3'-Dichlorobenzidine IL 3-Methylphenol (m-Cresol) IL IL 3-Nitroaniline IL 4-Bromophenyl phenyl ether 4-Chloro-3-methylphenol IL 4-Chloroaniline IL 4-Chlorophenyl phenylether IL 4-Methylphenol (p-Cresol) IL4-Nitroaniline IL 4-Nitrophenol IL Acenaphthene IL

Acenaphthylene

Aniline

IL

IL

Primary AB Certificate No.: 1002262023-17 Field of Testing /Matrix: RCRA (Solid & Hazardous Material) Anthracene IL Benzo(a)anthracene IL Benzo(a)pyrene IL Benzo(b)fluoranthene IL Benzo(g,h,i)perylene IL Benzo(k)fluoranthene IL IL Benzoic acid IL Benzyl alcohol bis(2-Chloroethoxy)methane IL bis(2-Chloroethyl) ether IL bis(2-Ethylhexyl) phthalate (DEHP) IL Butyl benzyl phthalate IL Carbazole IL Chrysene IL IL Dibenz(a,h) anthracene Dibenzofuran IL IL Diethyl phthalate Dimethyl phthalate IL Di-n-butyl phthalate IL Di-n-octyl phthalate IL Fluoranthene IL Fluorene IL Hexachlorobenzene IL Hexachlorobutadiene IL Hexachlorocyclopentadiene IL Hexachloroethane IL Indeno(1,2,3-cd) pyrene IL Isophorone IL Naphthalene IL Nitrobenzene IL n-Nitrosodiethylamine IL n-Nitrosodimethylamine IL n-Nitrosodi-n-propylamine IL n-Nitrosodiphenylamine IL IL n-Nitrosomethylethylamine Pentachlorobenzene IL Pentachlorophenol IL Phenanthrene IL Phenol IL Pyrene IL **Pyridine** IL Method EPA 8270C Mod LVI Acetochlor IL Alachlor IL **Atrazine** IL Butylate IL Cyanazine IL EPTC (Eptam, s-ethyl-dipropyl thio carbamate) IL Metolachlor IL Metribuzin IL IL Pendimethalin (Penoxalin)

Simazine

IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: RCRA (Solid & Hazardous Material) Trifluralin (Treflan)	IL
Method EPA 9012A Rev: 1 Cyanide	IL
Method EPA 9014 Rev: 0 Cyanide	IL
Method EPA 9020B Rev: 2 Total organic halides (TOX)	IL
Method EPA 9023 Rev: 0 Extractable organics halides (EOX)	IL
Method EPA 9034 Rev: 0 Sulfide	IL
Method EPA 9036 Rev: 0 Sulfate	IL
Method EPA 9045C Rev: 3 pH	IL
Method EPA 9060A Total organic carbon	IL
Method EPA 9065 Rev: 0 Total phenolics	IL
Method EPA 9214 Rev: 0 Fluoride	IL

Field of Testing /Matrix: SDWA (Potable Water)	
Method EPA 180.1 Rev: 2	
Turbidity	IL
Method EPA 200.7 Rev: 4.4	
Aluminum	IL
Barium	IL
Beryllium	IL
Boron	īL
Cadmium	IL
Calcium	IL
Chromium	IL
Copper	IL
Iron	IL
Magnesium	IL
Manganese	IL
Molybdenum	IL
Nickel	IL
Potassium	IL
Silver	IL
Sodium	IL
Vanadium	IL
Zinc	IL
Method EPA 200.8 Rev: 5.4	
Antimony	IL
Arsenic	IL
Barium	IL
Beryllium	IL
Cadmium	IL
Chromium	IL
Copper	IL
Lead	IL
Manganese	IL
Molybdenum	IL
Nickel	IL "
Selenium	IL "
Silver	IL "
Thallium	IL IL
Zinc	IL
Method EPA 245.1 Rev: 3	
Mercury	IL
Method EPA 335.4 Rev: 1	
Cyanide	IL
Method EPA 353.2 Rev: 2	
Nitrate	IL
Nitrate-nitrite	IL
Method SM 2130 B Rev: 20th ED	
Turbidity	IL
Method SM 2320 B Rev: 23rd ED	
Alkalinity as CaCO3	IL
Method SM 2340 B Rev: 23rd ED	,_
Hardness	IL
i iaiuness	IL

Certificate No.: 1002262023-17	Primary AB
Field of Testing /Matrix: SDWA (Potable Water)	
Method SM 2510 B Rev: 21st ED Conductivity	IL
Method SM 2540 C Rev: 23rd ED Total dissolved solids	IL
Method SM 4500-CI G Rev: 20th ED Total chlorine	IL
Method SM 4500-F C Rev: 23rd ED Fluoride	IL
Method SM 4500-H+ B Rev: 21st ED pH	IL
Method SM 4500-NO2 B Rev: 23rd ED Nitrite	IL
Method SM 4500-P E Rev: 23rd ED Orthophosphate as P	IL
Method SM 4500-SiO2 D Rev: 23rd ED Silica as SiO2	IL
Method SM 5310 C Rev: 21st ED Dissolved organic carbon (DOC) Total organic carbon	IL IL
End of Scope of Accreditation	

MISSOURI DEPARTMENT OF NATURAL RESOURCES

DRINKING WATER LABORATORY

CERTIFIED PARAMETER LIST

This is to certify that

Teklab, Incorporated

located at

5445 Horseshoe Lake Road, Collinsville, IL 62234

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

EPA 335.4 Total Cyanide

EPA 353.2Nitrate, Nitrite, Total Nitrate and Nitrite

EPA 245.1 Mercury

EPA 200.7

Barium, Beryllium, Cadmium, Chromium, Copper, Nickel

EPA 200.8

Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Copper, Lead, Nickel, Selenium, Thallium

SM4500F-C Fluoride

SM4500NO2-B Nitrite

Teklab, Incorporated

Expiration Date: January 31, 2025

Missouri Certificate No.: 930 Original Certifying State: Illinois